

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

LOCATION : STUYVESANT HIGH SCHOOL DATE PROJECT NO. 15-19125-0246

RESPIRABLE PARTICULATES ($\mu\text{g} / \text{m}^3$)

In Rooms with portable HEPA air Purifier

Time / Location	Room 740	Room 638	Room 333	Room 327
7:50	10	9	8	8
8:50	14	13	11	12
10:00	14	15	13	12
10:55	15	17	15	14
12:00	16	15	14	12
13:00	13	14	12	14

CITY_21MC100_003099015