

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

REPORT DATE: 11-15-01
CLIENT: NYC BOE
PROJECT ADDRESS: Stuyvesant HS (M477)/345 Chambers St.,
NY, NY 10007
PROJECT NO: 19125-0246
SAMPLED BY: Herant Antonyan
SAMPLE DATE: 11-14-01
DATE RECEIVED: 11-14-01
DATE ANALYZED: 11-14-01
SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT
01	9595	5th Floor Cafeteria Floor	<9.0	9.0
02	9595	5th Floor Cafeteria Window Sill	<4.5	4.5
03	9595	3rd Floor Aux. GYM Floor	<9.0	9.0
04	9595	3rd Floor Aux. GYM Window Sill	<18.0	18.0
05	9595	1st Floor Pool Area Floor	<9.0	9.0
06	9595	1st Floor Pool Area Window Sill	<4.7	4.7
07	9595	Auditorium Floor	<9.0	9.0
08	9595	1st Floor Lobby Area Floor	<9.0	9.0
09	9595	2nd Floor Lobby Area Floor	<9.0	9.0
10	9595	7th Floor Hallway Middle Floor	<9.0	9.0
11	9595	6th Floor Middle of Hallway Floor	<9.0	9.0
12	9595	Rm 1001 Floor	<9.0	9.0

CITY_21MC100_003101304

ATC ASSOCIATES, INC
104 E 25th Street, 10th Floor
New York, NY 10010
Tel. 212-353-8280
Fax 212-353-8306

13	9595	Rm 1001 Window Sill	<18.0	18.0
14	9595	Rm 902 Floor	<9.0	9.0
15	9595	Rm 902 Window Sill	<18.0	18.0
16	9595	Rm 125 Floor	<9.0	9.0
17	9595	Rm 125 Window Sill	<18.0	18.0
18	9595	Blank	<9.0	9.0
19	9595	Blank	<9.0	9.0

NOTE 1:



THE REPORTING LIMIT (RL) IS 18.0 μg

NOTE 2:

HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$,
Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.

CERTIFICATION AND SIGNATURESANALYSIS PERFORMED BY: REPORT PREPARED BY: 

ATC certifies that this report is an accurate and authentic report of results obtained from the laboratory analysis.

QUALITY ASSURANCE COORDINATOR: LABORATORY DIRECTOR: 

ATC Environmental Inc. (ATC) is accredited by the New York State Department of Health Environmental Laboratory Approval Program (NYS DOH ELAP) to perform analysis of lead in paint and dust wipes (ELAP #10879).