NYC 9/11 Public Portal Document

New York Environmental & Analytical Laboratories, Inc.

an independent full service testing & consulting firm

88 Harbor Road
Port Washington, NY 11050
Tel. (516) 944-9500 Fax. (516) 944-9507

CLIENT: ATC ASSOCIATES, INC.
104 EAST 25TH FLOOR
NEW YORK, NY 10010

PROJECT: M477

REPORT #: 212242
PROJECT #: 100401LC
SAMPLE DATE: 10/04/01
ANALYSIS DATE: 10/04/01
REPORT DATE: 10/05/01

ANALYTICAL REPORT
for
NON-METALS IN DRINKING WATER
(STANDARD METHODS 18TH EDITION)

SAMPLE NO	SAMPLE LOCATION	TURBIDITY (NTU)	ODOR (TON)	PH (mg/L)	FREE Cl_2 (mg/L)	CONDUCTIVITY (umhos/cm)
P01	10th floor hallway, by 1007	0.25	no odor observed	6.93	<0.05	83.3
P02	10th floor hallway, by 1025	0.2	no odor observed	6.97	<0.05	79.6
P03	9th floor hallway, by 903	1.15	no odor observed	7.01	<0.05	84.4
P04	9th floor hallway, by 925	0.45	no odor observed	7.01	<0.05	87.8
P05	8th floor hallway, by 809	0.4	no odor observed	6.95	<0.05	84.2
P06	8th floor hallway, by 827	0.55	no odor observed	6.96	<0.05	76.8
P07	7th floor hallway, by 709	0.35	no odor observed	6.78	<0.05	84.7
P08	7th floor hallway, by 727	0.35	no odor observed	6.99	<0.05	85.1

Li Tsang
Laboratory Director

LT/lg;

CITY_21MC100_003101582

NYC-WTC_000182861

NYC 9/11 Public Portal Document

New York Environmental & Analytical Laboratories, Inc.
an independent full service testing & consulting firm

88 Harbor Road
Port Washington, NY 11050
Tel. (516) 944-9500 Fax. (516) 944-9507

CLIENT: ATC ASSOCIATES, INC.
104 EAST 25TH FLOOR
NEW YORK, NY 10010

REPORT #: 212242
PROJECT #: 100401LC

SAMPLE DATE: 10/04/01
ANALYSIS DATE: 10/04/01
REPORT DATE: 10/05/01

PROJECT: M477

ANALYTICAL REPORT
for
NON-METALS IN DRINKING WATER
(STANDARD METHODS 18TH EDITION)

SAMPLE NO	SAMPLE LOCATION	TURBIDITY (NTU)	ODOR (TON)	PH (mg/L)	FREE Cl_2 (mg/L)	CONDUCTIVITY (umhos/cm)
P09	6th floor hallway, by east stairs E	0.45	no odor observed	6.97	<0.05	85.1
P10	6th floor hallway, by C623	0.45	no odor observed	6.94	<0.05	84.9
P11	6th floor gym	0.55	no odor observed	7.05	<0.05	85.3
P12	5th floor, by 505	0.7	no odor observed	7.04	<0.05	85.2
P13	5th floor, by 527	0.45	no odor observed	6.99	<0.05	83.7
P14	4th floor, by 407	0.55	no odor observed	6.99	<0.05	84.7
P15	4th floor, by 429	0.55	no odor observed	6.79	<0.05	83.8
P16	3rd floor by 307	0.55	no odor observed	6.92	<0.05	84.8

Li Tsang
Laboratory Director

LT/lg;

CITY_21MC100_003101583

NYC-WTC_000182862

NYC 9/11 Public Portal Document

New York Environmental & Analytical Laboratories, Inc.
an independent full service testing & consulting firm

88 Harbor Road
Port Washington, NY 11050
Tel. (516) 944-9500 Fax. (516) 944-9507

CLIENT: ATC ASSOCIATES, INC.
104 EAST 25TH FLOOR
NEW YORK, NY 10010

REPORT #: 212242
PROJECT #: 100401LC

SAMPLE DATE: 10/04/01
ANALYSIS DATE: 10/04/01
REPORT DATE: 10/05/01

PROJECT: M477

ANALYTICAL REPORT
for
NON-METALS IN DRINKING WATER
(STANDARD METHODS 18TH EDITION)

SAMPLE NO	SAMPLE LOCATION	TURBIDITY (NTU)	ODOR (TON)	PH (mg/L)	FREE Cl_2 (mg/L)	CONDUCTIVITY (umhos/cm)
P17	3rd floor, hallway	0.45	no odor observed	6.98	<0.05	84.1
P18	4th floor, dining by C540D	0.45	no odor observed	6.99	<0.05	78.9
P19	4th floor, kitchen	0.55	no odor observed	7.01	<0.05	84.6
P20	3rd floor, gym	0.7	no odor observed	7.01	<0.05	79.2
P21	2nd floor, by 211	0.45	no odor observed	7.04	<0.05	80.9
P22	2nd floor, by 229	0.55	no odor observed	6.94	<0.05	83.4
P23	2nd floor, by auditorium	0.55	no odor observed	6.95	<0.05	77.8
P24	1st floor hallway	0.55	no odor observed	6.96	<0.05	83.6

Li Tsang
Laboratory Director

LT/lg;

CITY_21MC100_003101584

NYC-WTC_000182863

NYC 9/11 Public Portal Document

New York Environmental & Analytical Laboratories, Inc.
an independent full service testing & consulting firm

88 Harbor Road
Port Washington, NY 11050
Tel. (516) 944-9500 Fax. (516) 944-9507

CLIENT: ATC ASSOCIATES, INC.
104 EAST 25TH FLOOR
NEW YORK, NY 10010

PROJECT: M477

REPORT #: 212242
PROJECT #: 100401LC

SAMPLE DATE: 10/04/01
ANALYSIS DATE: 10/04/01
REPORT DATE: 10/05/01

ANALYTICAL REPORT
for
NON-METALS IN DRINKING WATER
(STANDARD METHODS 18TH EDITION)

SAMPLE NO	SAMPLE LOCATION	TURBIDITY (NTU)	ODOR (TON)	PH (mg/L)	FREE Cl_2 (mg/L)	CONDUCTIVITY (umhos/cm)
P25	1st floor, swimming pool	0.55	no odor observed	7.05	<0.05	80.3
P26	1st floor hallway by real theater door	0.45	no odor observed	6.99	<0.05	84.6

Li Tsang
Laboratory Director

LT/lg;

CITY_21MC100_003101585

NYC-WTC_000182864