

104 EAST 25TH STREET, 10TH FLOOR
NEW YORK, NEW YORK 10010
PHONE: 212-353-8280 FAX: 212-353-8306

PAGE 1 OF 3

TOTAL # OF SAMPLES:

Client Name: NYC Board of Education

Project No: 41617-0546

Date: 10/11/2001

Project Address: New Stuyvesant HS (M477) / 345 Chambers street, New York, NY 10007

Turnaround Time: Rush

Investigator: Y. Efsthathiou

Project Manager: A. Andreou

Analysis Required: See Below

Sample ID#	Sample Location	Preservative	Container Capacity	Analysis Required	Lab Results				
					Pb	Cu	Fe	Z	Mn
M477-10/11 - 1M	8th FLOOR HALLWAY WATER FOUNTAIN BY ROOM # 827 - 1st DRAW	HNO3	250ml	Cu & Fe ONLY		0.19	0.22		
- 2M	————— ——— - 30 SEC FLASH	HNO3	250ml			0.18	0.18		
- 3M	————— ——— - 2 min FLASH	HNO3	250ml	↓		0.19	0.16		
- 4M	9th FLOOR HALLWAY WATER FOUNTAIN BY ROOM # 903 - 1st DRAW	HNO3	250ml	Cu & Fe ONLY		0.13	0.24		
- 5M	————— ——— - 30 seconds FLASH	HNO3	250ml			0.08	0.28		
- 6M	————— ——— - 2 minutes FLASH	HNO3	250ml	↓		0.08	0.22		
- 7M	9th Floor HALLWAY WATER FOUNTAIN BY ROOM # 825 - 1st DRAW	HNO3	250ml	Fe ONLY			0.26		
- 8M	————— ——— - 30 sec FLASH	HNO3	250ml	↓			0.16		

COMMENTS:

(ADDITIONAL COMMENTS

ON BACK)

RELINQUISHED BY (SIGNATURE BELOW)		DATE/TIME	RECEIVED BY (SIGNATURE BELOW)	DATE/TIME
<i>James E. Sullivan</i>		10/11/01	<i>[Signature]</i>	10/11/01 16:30
PRINT NAME (BELOW)			PRINT NAME (BELOW)	
TESTING PROVIDED BY:			LABORATORY DIRECTOR SIGNATURE	DATE/TIME
NY'S ELAP#	AIHA NLLAP#	PRINT NAME:		

ATC ASSOCIATES INC.
POTABLE WATER SAMPLING - CHAIN OF CUSTODY
 104 EAST 25TH STREET, 10TH FLOOR
 NEW YORK, NEW YORK 10010
 PHONE: 212-353-8280 FAX: 212-353-8306

PAGE 2 OF 3

TOTAL # OF SAMPLES: _____

Client Name: NYC Board of Education

Project No: 41617-0546

Date: 10/11/2001

Project Address: New Stuyvesant HS (M477) / 345 Chambers street, NEW YORK, NY 10007

Turnaround Time: Rush

Investigator: Y. Efstathiou

Project Manager: A. Andreou

Analysis Required: See Below

Sample ID#	Sample Location	Preservative	Container Capacity	Analysis Required	Lab Results				
					Pb	Cu	Fe	Z	Mn
M477-10/11-9M	9th FLOOR HALLWAY WATER FOUNTAIN BY ROOM #925 - 2 minutes FLASH	HNO3	250 ml	Fe ONLY			0.16		
-10M	10th FLOOR HALLWAY WATER FOUNTAIN BY ROOM #1007 - 1st DRAW	HNO3	250ml	Fe ONLY			0.23		
-11M	- 30 seconds FLASH	HNO3	250ml				0.25		
-12M	- 2 minutes FLASH	HNO3	250ml	↓			0.27		
-13M	5th FLOOR MALE VISITOR SHOWER - 1st DRAW	HNO3	250ml	ALL FIVE(S) METALS	0.003	0.31	0.27	0.15	0.03
-14M	- 30 SEC. FLASH	HNO3	250ml		<0.00	0.30	0.30	0.12	0.03
-15M	9th FLOOR CHEMISTRY PRE ROOM #925 - 1st DRAW	HNO3	250ml	↓	<0.00	0.71	0.23	0.14	0.03
-16M	- 30 SEC. DRAW	HNO3	250ml	↓	<0.00	0.64	0.25	0.13	0.03

COMMENTS: _____

(ADDITIONAL COMMENTS)

ON BACK)

RELINQUISHED BY (SIGNATURE BELOW)	DATE/TIME	RECEIVED BY (SIGNATURE BELOW)	DATE/TIME
<i>Y. Efstathiou</i>	10/11/01	<i>[Signature]</i>	10/11/01 16:30
PRINT NAME (BELOW)		PRINT NAME (BELOW)	
TESTING PROVIDED BY:	LABORATORY DIRECTOR SIGNATURE		DATE/TIME
NYSELAP#	AIHA NLLAP#	PRINT NAME:	

ATC ASSOCIATES INC.
 POTABLE WATER SAMPLING - CHAIN OF CUSTODY
 104 EAST 25TH STREET, 10TH FLOOR
 NEW YORK, NEW YORK 10010
 PHONE: 212-353-8280 FAX: 212-353-8306

PAGE 3 OF 3

TOTAL # OF SAMPLES: _____

Client Name: NYC Board of EducationProject No: 41617-0546Date: 10/11/2001Project Address: New Stuyvesant HS (M477) / 345 Chambers street, NEW YORK, NY 10007 Turnaround Time: RushInvestigator: Y. EfstathiouProject Manager: A. AndreouAnalysis Required: See Below

Sample ID#	Sample Location	Preservative	Container Capacity	Analysis Required	Lab Results				
					Pb	Cu	Fe	Z	Mn
M477-10/11-17M	BLANK	HNO3	250ml	ALL FIVE (5) METALS	<0.001	<0.01	<0.05	<0.01	<0.005
-18M	7th Floor, ROOM #705 -1ST DRAW	HNO3	250ml	ALL FIVE (5) METALS	0.006	0.06	0.22	0.09	0.04
-19M	-30 SEC FLASH	HNO3	250ml	ALL FIVE (5) METALS	<0.001	0.06	0.20	0.09	0.04
		HNO3							
		HNO3							
		HNO3							
		HNO3							
		HNO3							

COMMENTS: _____

(ADDITIONAL COMMENTS)

ON BACK)

RELINQUISHED BY (SIGNATURE BELOW)

DATE/TIME

RECEIVED BY (SIGNATURE BELOW)

DATE/TIME


 PRINT NAME (BELOW)

 10/11/01
 PRINT NAME (BELOW)


 PRINT NAME (BELOW)

 10/11/01 16:30
 PRINT NAME (BELOW)

TESTING PROVIDED BY:

LABORATORY DIRECTOR SIGNATURE

DATE/TIME

NYS ELAP#

AIHA NLLAP#

PRINT NAME:

CITY_21MC100_003101599

w:\lead\forms\NEWH20.xls