

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 3

TIME 1100


LOCATION PS 234 M DATE 2/1/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside Main Entrance		50.8	46.3	527	0	54	0
NW Corner		48.1	45.3	504	0	53	0
NE Corner		50.4	46.5	521	0	58	0
SW Corner		49.2	47.4	511	0	56	0
SE corner		50.1	48.6	515	0	53	0
Gym		64.8	40.6	638	0	44	0
Lunch Room	—	65.5	43.3	603	0	49	0
General Office	15	64.9	42.5	920	0	60	0
Hall by Stair 1	—	64.8	41.2	748	0	43	0
116	5	64.6	40.3	779	0	36	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Lots of activity. (Moving stuff around)

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.


Signature:  Date: 2/1/02

CITY_21MC100_003101616

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 3TIME 11:30LOCATION PS 234 M DATE 2/1/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
118	4	65.0	39.3	747	0	36	0
122	7	64.7	39.7	751	0	38	0
2nd FL. Stair H3	—	62.5	41.2	694	0	25	0
222	5	63.3	39.0	821	0	29	0
220	6	63.9	39.2	788	0	30	0
229	6	65.4	40.8	971	0	23	0
223	10	66.9	42.1	1032	0	23	0
215	3	68.2	41.7	999	0	25	0
206 (Assembly)	—	66.2	37.7	759	0	19	0
Library	—	67.2	39.8	985	0	34	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: rm 223 will be done again in the afternoon.The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/1/02

CITY_21MC100_003101617


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 3TIME 1200LOCATION PS 234 M DATE 2/1/02 PROJECT NO. 19125-279

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
(3rd FL) Stair #2		65.8	38.9	901	0	30	0
301		66.7	43.0	971	0	24	0
311		67.1	40.7	1199	0	26	0
306		66.8	39.3	1135	0	34	0
315		66.7	38.4	979	0	30	0
308		65.9	37.6	984	0	33	0
323		65.2	37.1	943	0	29	0
HALL BY STAIR #1		65.7	37.8	964	0	32	0
329		63.5	35.9	847	0	27	0
318		62.4	36.4	835	0	38	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: rm 311, 306 will be checked again in afternoon

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/1/02

CITY_21MC100_003101618