NYC 9/11 Public Portal Document

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: NYC BOE H.S. For Leadership & Public Services
90 Trinity Place, New York, NY

Received: 3/17/02 4:00:00 PM
ATC Group #: 7111
Analysis Date: 3/17/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5µ-5*	*5µ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
04 7111 -1	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 7111 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 7111 -3	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 7111 -4	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 7111 -5	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 7111 -6	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 7111 -7	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003102596

NYC-WTC_000183415

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: NYC BOE H.S. For Leadership & Public Services
90 Trinity Place, New York, NY

Received: 3/17/02 4:00:00 PM
ATC Group #: 7111
Analysis Date: 3/17/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5μ-5*	*5μ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
11 7111 -8	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 7111 -9	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 7111 -10	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 7111 -11	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 7111 -12	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 7111 -13	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
17 7111 -14	1829.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 7111 -15	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
19 7111 -16	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003102597

NYC-WTC_000183416

NYC 9/11 Public Portal Document

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Received: 3/17/02 4:00:00 PM
ATC Group #: 7111
Analysis Date: 3/17/02

Project: NYC BOE H.S. For Leadership & Public Services
90 Trinity Place, New York, NY

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volume*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5µ-5*	*5µ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
20 7111 -17	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
21 7111 -18	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003102598

NYC-WTC_000183417