

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Project: NYC BOE H.S. For Leadership & Public Services

90 Trinity Place, New York, NY

Received: 2/20/02

5:50:00 PM

ATC Group #: 6765

Analysis Date: 2/22/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
04 6765 -1	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 6765 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 6765 -3	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 6765 -4	1832.00	0.0899	0	CHRYSTILE	0	2	0.0093	44.48	0.0093	
08 6765 -5	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 6765 -6	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
10 6765 -7	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 6765 -8	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 2/20/02 5:50:00 PM
 ATC Group #: 6765
 Analysis Date: 2/22/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC BOE H.S. For Leadership & Public Services
 90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
12 6765 -9	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 6765 -10	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 6765 -11	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 6765 -12	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 6765 -13	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
17 6765 -14	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 6765 -15	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
19 6765 -16	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
20 6765 -17	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
21 6765 -18	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879