

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Received: 2/24/02

4:15:00 PM

ATC Group #: 6818

Analysis Date: 2/24/02

Project: NYC BOE H.S. For Leadership & Public Services
90 Trinity Place, New York, NY


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
04 6818 -1	1826.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 6818 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 6818 -3	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 6818 -4	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 6818 -5	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 6818 -6	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 6818 -7	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 6818 -8	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003103451

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 2/24/02 4:15:00 PM
ATC Group #: 6818
Analysis Date: 2/24/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: NYC BOE H.S. For Leadership & Public Services
90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
12 6818 -9	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 6818 -10	1824.00	0.0899	0	CHRYSTILE	0	2	0.0094	44.48	0.0094	
14 6818 -11	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 6818 -12	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 6818 -13	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 6818 -14	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 6818 -15	1816.00	4.8107	0	CHRYSTILE	75	32	0.5045	2379.8	0.5045	
19 6818 -16	1856.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
20 6818 -17	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
21 6818 -18	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003103452