

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 12/8/01 6:00:00 PM

ATC Group #: 6066

Analysis Date: 12/9/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Suyvesant H. S., 345 Chambers St., NY, NY
 Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
1 6066 -1	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
2 6066 -2	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
3 6066 -3	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
4 6066 -4	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
5 6066 -5	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
6 6066 -6	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
7 6066 -7	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
8 6066 -8	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003104631

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 12/8/01 6:00:00 PM

ATC Group #: 6066

Analysis Date: 12/9/01


Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
 Exterior and Interior of Building and Roof


**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm')	(S/cc)	
9 6066 -9	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
10 6066 -10	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
11 6066 -11	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
12 6066 -12	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
13 6066 -13	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
14 6066 -14	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
15 6066 -15	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
16 6066 -16	1960.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
17 6066 -17	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
18 6066 -18	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003104632

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 12/8/01 6:00:00 PM

ATC Group #: 6066

Analysis Date: 12/9/01

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: New Stuyvesant H. S., 345 Chambers St., NY, NY
 Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
19 6066 -19	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
20 6066 -20	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
21 6066 -21	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003104633