

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 12/11/01 9:00:00 PM

ATC Group #: 6080

Analysis Date: 12/12/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
1 6080 -1	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
2 6080 -2	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
3 6080 -3	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
4 6080 -4	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
5 6080 -5	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
6 6080 -6	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
7 6080 -7	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
8 6080 -8	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003104690

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 12/11/01 9:00:00 PM

ATC Group #: 6080

Analysis Date: 12/12/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S., 345 Chambers St., NY, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**


Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures 0.5 μ -5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
9 6080 -9	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
10 6080 -10	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
11 6080 -11	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
12 6080 -12	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
13 6080 -13	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
14 6080 -14	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
15 6080 -15	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
16 6080 -16	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
17 6080 -17	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045
18 6080 -18	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044

MARK PEYSAKHOV

MICHAEL A. GORYCKI, Ph.D.

Analyzed by:

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003104691

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 12/11/01 9:00:00 PM

ATC Group #: 6080

Analysis Date: 12/12/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**


Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5 μ -5	5 μ		(S/mm ²)	(S/cc)	
19 6080 -19	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
20 6080 -20	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
21 6080 -21	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_003104692