

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 11/10/01 9:00:00 PM**ATC Group #:** 5874**Analysis Date:** 11/11/01**Fax:** (212) 475-4122 **Phone:** (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , NY
Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
1 - 5874 -1	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
2 - 5874 -2	1920.00	0.0450	0	CHRYSTILE	1	0	0.0045	22.24	0.0045	
3 - 5874 -3	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
4 - 5874 -4	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
5 - 5874 -5	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
6 - 5874 -6	1944.00	0.0450	0	CHRYSTILE	1	0	0.0044	22.24	0.0044	
7 - 5874 -7	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
8 - 5874 -8	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by: 

MICHAEL A. GORYCKI, Ph.D.

Approved by: 

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 11/10/01 9:00:00 PM

ATC Group #: 5874

Analysis Date: 11/11/01

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , NY
Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5μ-5	5μ		(S/mm ²)	(S/cc)	
9 - 5874 -9	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
10 - 5874 -10	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
11 - 5874 -11	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
12 - 5874 -12	1928.00	0.0450	0	CHRYSTOLE	1	0	0.0044	22.24	0.0044	
13 - 5874 -13	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
14 - 5874 -14	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
15 - 5874 -15	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
16 - 5874 -16	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
17 - 5874 -17	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
18 - 5874 -18	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 11/10/01 9:00:00 PM

ATC Group #: 5874

Analysis Date: 11/11/01

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: New Stuyvesant H. S. , 345 Chambers St., NY , NY
Exterior and Interior of Building and Roof

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

<i>Sample</i>	<i>Volume</i>	<i>Area Analyzed</i>	<i>Non Asb</i>	<i>Asbestos Type(s)</i>	<i>Structures</i>		<i>Analytical Sensitivity (S/cc)</i>	<i>Asbestos Concentration</i>		<i>Notes</i>
					<i>0.5µ-5</i>	<i>5µ</i>		<i>(S/mm²)</i>	<i>(S/cc)</i>	
19 - 5874 -19	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
20 - 5874 -20	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	
21 - 5874 -21	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044	

ROMAN PEYSAKHOV

Analyzed by:

RRuy

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Michael A. Gorycki

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879