

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 2/20/02 5:30:00 PM
 ATC Group #: 6764
 Analysis Date: 2/22/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: PS 89M 201 Warren Street, New York, NY
 Playground, Roof All Floors Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5 5μ		Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²) (S/cc)		Notes
01 6764 -1	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
02 6764 -2	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
03 6764 -3	1870.00	0.0450	0	CHRYSTILE	0	1	0.0046	22.24	0.0046	
04 6764 -4	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
05 6764 -5	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
06 6764 -6	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
07 6764 -7	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
08 6764 -8	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 2/20/02 5:30:00 PM
ATC Group #: 6764
Analysis Date: 2/22/02

Fax: (212) 475-4122 **Phone:** (212) 477-8941


Project: PS 89M 201 Warren Street, New York, NY
 Playground, Roof All Floors Hallway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area	Non	Asbestos	# Structures		Analytical	Asbestos		Notes
		Analyzed	Asb	Type(s)	0.5µ-5	5µ	Sensitivity (S/cc)	Concentration (S/mm ²)	(S/cc)	
09 6764 -9	1809.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 6764 -10	1809.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
11 6764 -11	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048	
12 6764 -12	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
13 6764 -13	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
14 6764 -14	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
15 6764 -15	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
16 6764 -16	1870.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879