



600 West Cummings Park, Suite 6500
Woburn, Massachusetts 01801-6350
www.atc-enviro.com
781.932.9400
Fax 781.932.6211

February 6, 2002

Mr. Bernard P. Orlan
Director, Environmental Health & Safety
New York City Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101-4008

**Re: Indoor Air Quality Assessment
P.S. 89M
ATC Project No. 15-19125-0297**

Dear Mr. Orlan:

ATC Associates Inc. (ATC) is pleased to provide this report of indoor air quality (IAQ) measurements collected on February 5, 2002, at the referenced school. The New York City Board of Education (BOE) requested these measurements to evaluate air quality in the school building prior to re-occupancy.

SCOPE OF WORK

ATC conducted this evaluation to assess the basic parameters of temperature, relative humidity, carbon dioxide (CO₂) and carbon monoxide (CO).

ATC measured temperature, relative humidity, CO₂ and CO with a Q-Trak[®] Model 8551, manufactured by TSI, Inc.

ATC measured concentrations of respirable particulates (PM_{2.5}) with a Dust-Trak[®] Aerosol Monitor Model 8520, manufactured by TSI, Inc.

ATC measured concentrations of TVOCs using a RAE Systems, Inc. MiniRAE[®] photoionization detector (PID).

Mr. Jimmy Choy, Industrial Hygienist of ATC's New York City office, conducted the assessment.

ATC's findings and conclusions are based on a visual inspection, real-time environmental measurements and conditions present in the school at the time of the assessment.

The assessment was performed consistent with generally accepted indoor air quality assessment practices. As with all such assessments, there were inherent limitations created by constraints of time, operational and work practice variability, variations in indoor air quality parameters and sampling and analytical accuracy. The results of the sampling represent conditions found on the dates of the survey and may not represent conditions found at other times. The information presented in this report should be used by the BOE as a guide to assess the need for further improvements in current indoor air quality control activities.

EVALUATION CRITERIA

Currently, there are no regulatory standards for indoor air quality in non-industrial buildings, such as offices and schools. For the real-time data collected, ATC uses the commonly accepted guidelines cited in the following publications:

- *Ventilation for Acceptable Indoor Air Quality (ASHRAE 62-1999)*, American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE);
- *Thermal Environmental Conditions for Human Occupancy (ASHRAE 55-1992)*;
- *Industrial Hygienists Guide to Indoor Air Quality Investigations* (1993), American Industrial Hygiene Association (AIHA).

Table 1 lists target guidelines for the parameters that ATC evaluated during this investigation. Meeting one, some, or all of the listed values does not assure that acceptable indoor air quality will be achieved at all times.

TABLE 1
TARGET GUIDELINES FOR INDOOR AIR QUALITY PARAMETERS EVALUATED

PARAMETER	TARGET LEVEL	AGENCY OR ORGANIZATION
Carbon Dioxide (CO ₂)	<700 parts per million (ppm) above background level	ASHRAE 62
Carbon Monoxide (CO)	9 ppm	ASHRAE 62 (adopted from USEPA NPAAQS)
Respirable Particulates (PM _{2.5})	65 micrograms per cubic meter of air (µg/m ³) 24-hour average	USEPA NPAAQS
	40 µg/m ³ 24-hour average	USEPA - recommendation for children/sensitive individuals
Temperature	Summer: 73-79°F at 50% RH Winter: 68-75°F at 50% RH	ASHRAE 55
Relative Humidity	30 - 60 %	ASHRAE 55
Total Volatile Organic Compounds (TVOC)	1 ppm	AIHA

USEPA = United States Environmental Protection Agency
NPAAQS = National Primary Ambient-Air Quality Standard
AIHA = American Industrial Hygiene Association

REAL-TIME ENVIRONMENTAL MEASUREMENTS

ATC collected eighty (80) sets of real-time environmental measurements consisting of eight (8) outdoors and thirty-two (32) inside in the morning (A.M.) and the same number of readings in the afternoon (P.M.). All five floors of the school were surveyed. The field data sheets are found in the Attachment. Readings began at 8:00 A.M. and concluded after 3:30 P.M. The results are described below:

Temperature

Indoor dry bulb temperature measurements ranged from 64.5°F to 70.4°F (A.M.) and 64.6°F to 75.0°F (P.M.). Eleven (11) measurements in the morning and four (4) measurements in the afternoon were below the range of 68 to 75°F (at 50 percent relative humidity) recommended by ASHRAE Standard 55-1992 during the heating season (wintertime conditions). The average outdoor temperature was 38.9°F (A.M.) and 34.3°F (P.M.).

Relative Humidity

The relative humidity indoors ranged from 10.4 to 22.8 percent (A.M.) and 10.2 to 19.1 percent (P.M.). All readings were below the ASHRAE-recommended range of 30 to 60 percent for occupant comfort. The outdoor relative humidity averaged 17.7 percent (A.M.) and 16.1 percent (P.M.).

Carbon Dioxide Concentration

Carbon dioxide concentrations indoors ranged from 460 to 1326 ppm (A.M.) and 480 to 1102 ppm (P.M.). Two (2) CO₂ measurements collected in the morning were above the ASHRAE Standard 62-1999 recommended maximum concentration of <700 ppm above the background level. The outdoor (background) CO₂ concentrations averaged 456 ppm (A.M.) and 459 ppm (P.M.). Therefore, the maximum acceptable level of CO₂ at this location was 1159 ppm (background level + 700 ppm). The highest indoor level was measured in Classroom 404. Levels above the recommended maximum do not indicate a health risk. Carbon dioxide measurements are used as an indicator of available outdoor air. The primary source of CO₂ indoors is occupant respiration. The 2nd and 3rd floors of the school building were not occupied during ATC's assessment.

Carbon Monoxide Concentration

Carbon monoxide concentrations indoors were 0 ppm for all readings. These concentrations were below the ASHRAE guideline of 9 ppm. The outdoor CO concentration was also 0-1 ppm.

Respirable Particulates (PM_{2.5})

Respirable particulate concentrations* indoors ranged from 6 µg/m³ to 19 µg/m³ (A.M.) and 6 µg/m³ to 13 µg/m³ (P.M.). All indoor measurements were below the NPAAQS of 65 µg/m³ 24-hour average concentration of particulate matter 2.5 micrometers or less in aerodynamic diameter. The average PM_{2.5} concentration* for the entire school building was approximately 12 µg/m³ (A.M.) and 9 µg/m³ (P.M.). All A.M. and P. M. indoor measurements were also

Mr. Bernard P. Orlan
Indoor Air Quality Assessment
P. S. 89M

February 6, 2002

Page 4

ATC Project No. 15-19125-0297

below the USEPA recommended concentration of $40 \mu\text{g}/\text{m}^3$ for sensitive individuals such as asthmatic people and children. The outdoor respirable particulate concentration averaged $23 \mu\text{g}/\text{m}^3$ (A.M.) and $10 \mu\text{g}/\text{m}^3$ (P.M.).

* The measurements made during this assessment were instantaneous readings, the NPAAQS is a 24-hour average.

TVOC Concentration

TVOCs were not detected (0.0 ppm) anywhere inside or outside the building.

OBSERVATIONS

During this assessment, ATC noted the following:

- The interior of the building appeared clean and free of dust and debris;
- The school was partially occupied (I.S. 89) at the time of the assessment;
- No smoke odor was detected in the building.


FINDINGS

Based on the real-time measurements, the following findings are presented:

1. Respirable particulate, CO_2 , CO and TVOC concentrations were within applicable guidelines;
2. Eleven (11) measurements of temperature in the morning and four (4) measurements in the afternoon were below the recommended range;
3. All indoor measurements of relative humidity were below the ASHRAE recommended range of 30 to 60 percent for occupant comfort.

It is our pleasure to provide these indoor air quality services to the New York City Board of Education. If you have any questions about this report, please call (212) 353-8280, extension 261 or 212.

Sincerely,
ATC ASSOCIATES INC.



Andreas C. Andreou
Senior Project Manager

Reviewed by:



James R. Cohn, CIH, CSP
Regional Manager
Industrial Hygiene Division

Attachment