

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8


TIME 800

LOCATION PS89 M DATE 2/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Outside SE Corner		47.0	32.5	463	0	32	0
Outside South Exit		46.8	31.9	465	0	27	0
Outside SW Corner		47.3	31.5	468	0	30	0
Outside NW Corner		47.9	31.3	466	0	28	0
Outside North Exit		48.3	30.9	460	0	30	0
Outside NE Corner		47.5	30.5	463	0	33	0
Outside East Side		47.0	30.2	463	0	30	0
Playground South		46.4	29.9	460	0	28	0
Playground North		46.0	29.7	462	0	29	0
Inside North Exit		71.4	27.3	528	0	12	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/27/02

CITY_21MC100_003109860

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 8

TIME 830

LOCATION PS89 M DATE 2/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Inside South Exit		71.6	26.8	530	0	13	0
Hall by Cafeteria		70.9	27.0	522	0	14	0
Cafeteria		70.7	33.0	538	0	14	0
Dance Rm.		70.4	31.1	512	0	9	0
1st. Fl. Hall by Stair 2		70.2	30.2	536	0	15	0
143 (Hall)		69.7	29.3	534	0	14	0
132	4	69.8	29.5	555	0	15	0
132C	2	70.3	29.4	587	0	13	0
1st. Fl. Hall by Elevator	—	72.3	27.4	520	0	16	0
501	1	73.5	26.3	517	0	9	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chay Date: 2/27/02

CITY_21MC100_003109861

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT


Page 3 of 8

TIME 900LOCATION PS89 MDATE 2/27/02PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
501 (Hall)	—	73.6	26.3	540	0	14	0
502	1	73.7	25.6	532	0	14	0
5th FL. Hall by Stair 3	—	73.7	25.0	516	0	15	0
504	—	73.5	25.4	535	0	14	0
506	32	73.9	28.8	899	0	16	0
515 (Hall)	—	73.9	25.0	546	0	13	0
508	34	74.0	25.7	603	0	17	0
510	31	74.6	30.8	1019	0	17	0
512	2	74.5	25.5	640	0	16	0
520 (Hall)		74.3	24.6	560	0	15	0
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/27/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 8

TIME 930LOCATION PS89 MDATE 2/27/02PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Hall by stairs 2	—	74.4	24.4	574	0	16	0
526	31	74.3	28.1	1069	0	15	0
528	32	73.3	27.2	888	0	15	0
530 (HALL)	—	73.1	25.1	629	0	15	0
517	2	73.2	24.0	560	0	13	0
532	30	73.1	26.6	939	0	17	0
419	12	72.4	25.8	566	0	13	0
432	1	72.6	25.3	565	0	12	0
430 (HALL)	—	72.6	25.2	549	0	15	0
430	2	72.8	25.3	550	0	13	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chan Date: 2/27/02

CITY_21MC100_003109863

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8

TIME 1000

LOCATION PS89 M DATE 2/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOCs (ppm)
428 (Hall)		72.7	24.9	547	0	14	0
428	—	72.5	24.6	507	0	15	0
426	—	72.3	25.1	520	0	14	0
420 (Hall)	—	72.2	24.9	557	0	16	0
410 (Hall)	—	72.5	25.0	530	0	15	0
408	26	73.1	27.8	859	0	17	0
Hall by Elevator	—	73.3	25.5	566	0	15	0
404	32	74.0	28.1	895	0	21	0
402	32	73.8	28.4	929	0	22	0
401	1	73.9	24.8	589	0	10	0
Guideline levels ASHRAE/AMIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jim Chen Date: 2/27/02

CITY_21MC100_003109864

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 8

TIME 1030LOCATION PS89 M DATE 2/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Stair 3	—	73.5	22.8	534	0	15	0
Hall by Stair 3	—	72.2	24.8	560	0	16	0
301	—	72.5	24.5	530	0	16	0
302	3	71.5	24.7	577	0	15	0
304	2	71.8	24.8	559	0	16	0
Hall by Elevator	—	71.6	25.4	535	0	15	0
306	1	71.8	25.3	538	0	17	0
307 (Hall)	—	71.7	25.4	533	0	15	0
315 (Gym)	—	71.0	25.6	529	0	15	0
308	2	70.1	25.7	564	0	15	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jimmy Chan Date: 2/27/02

CITY_21MC100_003109865

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8

TIME 1100LOCATION PS89 M DATE 2/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
310	—	70.1	26.1	561	0	16	0
316	1	70.3	26.5	559	0	18	0
326	1	71.0	26.3	557	0	16	0
328	2	71.0	26.4	571	0	16	0
330	2	71.2	26.6	565	0	17	0
332	—	70.9	26.0	507	0	14	0
319	—	70.1	24.8	527	0	15	0
Hall by Stair 1	—	70.3	25.7	550	0	17	0
Stair 1	—	70.4	26.6	540	0	15	0
219	1	70.2	26.6	542	0	14	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 2/27/02

CITY_21MC100_003109866

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8TIME 1130LOCATION PS89 M DATE 2/27/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
232	2	70.7	27.5	568	0	13	0
230	2	70.9	26.9	551	0	14	0
230 (Hall)	—	71.0	26.8	544	0	14	0
228	2	71.6	26.8	548	0	16	0
226	2	71.8	26.4	540	0	18	0
Auditorium	—	71.1	25.5	503	0	13	0
204	—	70.9	25.3	536	0	18	0
201	1	68.8	24.8	504	0	14	0
202	2	69.4	26.9	528	0	18	0
Hall by Elevator	—	70.4	26.5	529	0	15	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jing Chen Date: 2/27/02

CITY_21MC100_003109867