

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 8

TIME 800

LOCATION PS89 M DATE 2/28/02 PROJECT NO. 19125-297

Location	Occup.	Temperature ("F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
NE Corner Outside		33.3	32.0	435	0	20	0
North W Corner Outside		33.9	31.8	441	0	22	0
Exit South Outside		34.8	32.3	439	0	20	0
SE Corner Outside		34.6	31.9	435	0	19	0
SW Corner Outside		34.0	32.3	430	0	23	0
North Exit Outside		34.5	32.5	435	0	21	0
By Air Intake Outside		34.0	33.0	431	0	19	0
Playground North		34.9	31.4	426	0	23	0
Playground South		35.1	31.0	430	0	25	0
Exit North Inside		71.0	26.5	900	0	12	0
Guideline levels ASHRAE/AHIA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Ji Ch Date: 2/28/02

CITY_21MC100_003109873

ATC ASSOCIATES, INC.


Page 2 of 8

INDOOR AIR QUALITY FIELD REPORT

TIME 8:30LOCATION PS89 MDATE 2/27/02PROJECT NO. 19135-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
South Exit Inside		65.3	26.5	825	0	13	0
Dance rm		70.1	26.8	541	0	7	0
Cafeteria		70.5	18.0	589	0	9	0
Hall by Elevator		65.7	16.2	871	0	12	0
501	1	68.8	17.0	599	0	7	0
502 (Hall)	-	69.5	16.1	620	0	14	0
504 (Hall)	-	69.5	15.8	641	0	16	0
5th FL. Hall by Elevator	-	69.7	15.6	643	0	14	0
506	24	70.3	20.9	1079	0	18	0
515 (Hall)	-	70.9	16.1	699	0	12	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/27/02

CITY_21MC100_003109874

ATC ASSOCIATES, INC.

Page 3 of 8TIME 900


INDOOR AIR QUALITY FIELD REPORT

LOCATION PS89 MDATE 2/28/02PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
508	3	70.9	15.1	648	0	14	0
510	31	72.3	19.9	1079	0	13	0
52 (Hall)	—	72.3	16.6	865	0	22	0
526	1	71.8	15.5	719	0	10	0
528	26	71.5	16.3	810	0	12	0
517	1	71.1	13.9	579	0	9	0
530 (Hall)	—	70.9	13.5	635	0	13	0
532	31	71.1	17.5	848	0	12	0
519 (Hall)	—	71.3	17.0	827	0	12	0
Stair 1 (Stair)	—	71.1	15.5	785	0	15	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/28/02

ATC ASSOCIATES, INC.

Page 4 of 8

TIME 930

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS89 M DATE 2/28/02 PROJECT NO. 19135-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
419	1	70.5	15.2	661	0	10	0
432	14	71.3	17.7	836	0	10	0
430	21	71.1	17.7	883	0	9	0
430 (Hall)	-	71.3	14.9	578	0	11	0
426	-	70.5	16.9	588	0	9	0
Hall by Stair 2	-	70.6	16.0	580	0	10	0
410 (Hall)	21	71.2	15.5	645	0	12	0
408	20	71.6	17.5	789	0	22	0
415	3	71.8	16.5	709	0	~~10~~ 10	0
415 (Hall)	-	71.7	16.8	680	0	12	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 2/28/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 5 of 8TIME 1000LOCATION PS89 M DATE 2/28/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
404	30	72.3	16.5	860	0	15	0
402	32	72.1	18.3	1100	0	14	0
401	4	71.5	14.9	658	0	7	0
Stair 3 (4th FL.)	—	71.2	14.2	628	0	13	0
319 (Hall)	—	69.7	13.7	654	0	10	0
332	18	70.5	15.4	902	0	8	0
332 (Hall)	—	70.7	15.1	805	0	10	0
330	17	71.0	16.0	818	0	10	0
328	1	70.6	14.0	709	0	9	0
326	2	71.4	13.7	652	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.


Signature: Jin Chen Date: 2/28/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 6 of 8TIME 1030LOCATION PS89 MDATE 2/28/02 PROJECT NO. 19125-297

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
324 (Hall)	—	71.4	14.0	635	0	11	0
Hall by Stair 2	—	71.1	13.5	600	0	11	0
316	—	70.8	12.5	536	0	13	0
315 (Hall)	—	70.5	12.9	604	0	14	0
310	2	70.0	13.5	594	0	11	0
315 (Gym)	30	67.9	14.0	599	0	12	0
308 (Hall)	—	68.4	14.3	593	0	11	0
306	1	69.4	14.5	640	0	10	0
301	20	70.8	14.9	669	0	7	0
304	16	72.0	15.9	634	0	12	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/28/02

CITY_21MC100_003109878

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 7 of 8


TIME 1100

LOCATION PS89 M DATE 2/28/02 PROJECT NO. 19125-297

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	VOC (ppm)
302	17	72.1	14.2	749	0	12	0
305 (Hall)	—	71.0	13.6	623	0	11	0
201 (Hall)	—	71.1	13.3	638	0	11	0
202	28	70.8	14.5	817	0	14	0
Hall by Stair 3	—	70.9	13.5	680	0	10	0
204	22	71.8	15.2	859	0	11	0
Auditorium	—	70.1	11.8	534	0	7	0
207 (Hall)	—	70.5	12.1	552	0	9	0
Hall by Stair 2	—	71.3	12.9	567	0	10	0
226	10	72.0	14.8	710	0	12	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 2/28/02

CITY_21MC100_003109879

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 8 of 8TIME 1:50LOCATION P589 M DATE 2/28/02 PROJECT NO. 19125-297

Location	Occup	Temperature	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	Total Particulate (µg/m³)
217C (Hall)	—	72.2	13.7	633	0	9	0
228	16	71.9	15.8	920	0	8	0
228 (Hall)	—	72.1	14.0	704	0	10	0
230	12	71.7	14.7	808	0	10	0
232	3	71.0	15.8	699	0	8	0
219	16	71.5	14.8	904	0	10	0
2nd FL. Hall by Stair 1	—	71.8	14.2	720	0	8	0
2nd FL. Stair 1	—	70.0	13.5	625	0	10	0
143 (Hall)	—	70.5	13.0	580	0	8	0
132C	2	70.9	13.2	595	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jim Chey Date: 2/28/02