

AIC ASSOCIATES, INC**104 E 25th Street, 10th Floor****New York, NY 10010****Tel. 212-353-8280****Fax 212-353-8306**

REPORT DATE: 08-14-02

CLIENT: Taylor Environmental Group, Inc.

PROJECT NAME: SCA/Stuyvesant HS
345 Chambers Street, NY

PROJECT NUMBER: M477-15217-29881

SAMPLED BY: Client

SAMPLE DATE: 08-13-02
DATE RECEIVED: 08-13-02
DATE ANALYZED: 08-13-02

SAMPLE MEDIA: Dust Wipe Sample
ANALYSIS REQUIRED: Method EPA 3050/7420

ANALYSIS RESULTS

SAMPLE ID	BATCH NO.	SAMPLE DESCRIPTION	LEAD CONCENTRATION ($\mu\text{g}/\text{ft}^2$)	DETECTION LIMIT ($\mu\text{g}/\text{ft}^2$)
LW-01	21112	2nd Floor Corridor Supply O/S East Stair	<9.0	9.0
LW-02	21112	2nd Floor Corridor Supply O/S Rm C221	<9.0	9.0
LW-03	21112	2nd Floor Corridor Supply O/S West Stair	<9.0	9.0
LW-04	21112	2nd Floor Rm 225 Return	14.7	9.0
FB-01	21112	Field Blank	<9.0 μg	9.0 μg
FB-02	21112	Field Blank	<9.0 μg	9.0 μg

NOTE 1:**THE REPORTING LIMIT (RL) IS 18.0 μg** **NOTE 2:**HUD Guidelines for final clearance dust wipe samples: Floor 40 $\mu\text{g}/\text{ft}^2$, Window sills 250 $\mu\text{g}/\text{ft}^2$, Window wells 400 $\mu\text{g}/\text{ft}^2$, Exterior surfaces 800 $\mu\text{g}/\text{ft}^2$.**NOTE 3:**Blank units are in μg