

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-230-0051 Fax: 212-290-0058 Email:



Attn: H.A. Bader Consultants
88 Bleecker St
Suite 4E
New York, NY 10012

Fax: (212) 477-8941

Phone: 212-475-4122

Project: BMCC 30 West Broadway NY, NY

Customer ID: HAB50

Customer PO:

Received: 01/10/02 9:08 AM

EMSL Order: 030200417

EMSL Project ID:

Analysis Date: 1/10/2002

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Ash	Asbestos Type(s)	# Structure 0.5µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mml) (S/cc)	Notes
3/02 F-26 0200417-0001	1850.00		0	Overloaded				
3/02 F-27 0200417-0002	1850.00		0	Overloaded				
3/02 F-28 0200417-0003	1850.00	0.0500	7	None Detected		0.0042	<20.00 <0.0042	
3/02 F-29 0200417-0004	1850.00	0.0500	9	None Detected		0.0042	<20.00 <0.0042	
3/02 F-30 0200417-0005	1850.00	0.0500	11	None Detected		0.0042	<20.00 <0.0042	
3/02 F-31 0200417-0006	1850.00		0	Overloaded				
3/02 F-32 0200417-0007	1850.00	0.0500	16	None Detected		0.0042	<20.00 <0.0042	
3/02 F-33 0200417-0008	1850.00	0.0500	11	None Detected		0.0042	<20.00 <0.0042	
3/02 F-34 0200417-0009	1850.00	0.0500	8	None Detected		0.0042	<20.00 <0.0042	
3/02 F-35 0200417-0010	1850.00	0.0500	5	None Detected		0.0042	<20.00 <0.0042	
3/02 F-36 0200417-0011	1750.00	0.0500	9	None Detected		0.0044	<20.00 <0.0044	

Jose Arriaga (13)

Laboratory Manager
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in this report, which is dependent on volume collected by non-laboratory personnel. The lab is only responsible for data reported in this report. This report may not be reproduced, stored in a retrieval system, or transmitted in any form or by any means, electronic, mechanical, photocopying, recording, or by any information storage and retrieval system, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report is also only for the samples reported above. Quality control data (including 65% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

Created for NVLAP #101048-8, NY State ECLAP #11505

TEM AHERA-1

091