



MORETRENCH AMERICAN CORPORATION

www.moretrench.com

March 18, 2002

Serial Letter 01-4906-77

VIA FACSIMILE (3 wfc)
(212) 640-9207

Mr. Brian Peters
Bovis Lend Lease LMB, Inc.
200 Park Avenue
New York, NY 10166

Total # of Pages: 7

**RE: World Trade Center Dewatering
Contract No. 20020004649
MTA Job 01-4906
Water Analyses**

Dear Brian:

Attached find complete results of the analysis of the water samples taken from the WTC site on March 11, 2002. MTBE levels for the sump discharge (B-6 30 hp sump pump) and dewatering wells (Main Discharge) are 45 ppb and 4.7 ppb respectively.

Chlorodifluoromethane is 160 ppb in the sump discharge and not detected in the dewatering well discharge.

We are also forwarding a copy of the table which tracks MTBE concentration for all of the water sample testing which has been performed on the site.

Very truly yours,
MORETRENCH AMERICAN CORPORATION

John F. Donohoe /sk

John F. Donohoe
President

cc: Billy Klingler, MTA

200/1001007

MORETRENCH AMERICAN

03/18/2002 17:39 FAX 973 627 3950

CITY_21MC100_004696496