



MORETRENCH AMERICAN CORPORATION

www.moretrench.com

April 30, 2002

Serial Letter 01-4906-105

100 Stickle Avenue
P.O. Box 316
Rockaway, N.J. 07866
Tel: (973) 627-2100
Fax: (973) 627-3950 / 627-6078

VIA FACSIMILE (3 wfc)
(212) 640-9207

Mr. Brian Peters
Bovis Lend Lease LMB, Inc.
200 Park Avenue
New York, NY 10166

Total # of Pages: 8

RE: World Trade Center Dewatering
Contract No. 20020004649
MTA Job 01-4906
Water Analyses

Dear Brian:

Attached find complete results of the analysis of the water samples taken from the WTC site on April 22, 2002. MTBE level for the sump discharge (B-6 30 hp sump pump) was 32 ppb and for the dewatering wells (Main Discharge) was 2.0 ppb.

Chlorodifluoromethane was 180 ppb in the sump discharge and 8.4 ppb in the dewatering well discharge.

We are also forwarding a copy of the tables which track MTBE and Chlorodifluoromethane concentrations for all of the water sample testing which has been performed on the site.

Very truly yours,
MORETRENCH AMERICAN CORPORATION

A handwritten signature in black ink that reads "John F. Donohoe" followed by a stylized "sk" or "15k" mark.

John F. Donohoe
President

cc: Billy Klingler, MTA