

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

PCM

WARREN & PANZER ENGINEERS, P. C. AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

P.C. U

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

CLIENT: DDC
PROJECT: AMERICAN EXPRESS
LOCATION: 31st Floor

W&P FILE #: 1017-08-01
LABORATORY: 720
ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II

CONTACT: _____
LLW#: _____
SCA JOB#: _____

TECHNICIAN: _____

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP	FLOW RATE START	STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTRATION (Hb/cc)
001	ELEVATOR LOBBY (South)	8		15	15	15:58	18:08	130	1950	0.003
002	South East corner	8		15	15	16:00	18:10	130	1950	0.007
003	East side	8		15	15	16:01	18:11	130	1950	<0.001
004	North East corner	8		15	15	16:03	18:13	130	1950	<0.001
005	ELEVATOR LOBBY (North)	8		15	15	16:05	18:15	130	1950	0.004
006	North side	8		15	15	16:07	18:17	130	1950	0.004
007	West side	8		15	15	16:10	18:20	130	1950	0.001
008	FIELD BLANK									-
009	"									-

COMMENTS:

SAMPLE BY: PRANABH A. SARA DATE: 10/9/01
SIGNATURE: [Signature]
RELEASED BY: [Signature] DATE: 10/9/01
SIGNATURE: [Signature]
RECEIVED BY: S. GARCIA DATE: 10/10/01
SIGNATURE: [Signature]

N011074

SAMPLE TYPE CODES	
① - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	⑧ - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

CITY_21MC100_002941141