

12/10/2001 15:26

EMSL Analytical, Inc.

107 Haddon Ave. Westmont, NJ 08108

Phone: (856) 858-4800 Fax: (856) 858-4980 Email: asiegol@EMSL.com

EMSL

Attn: Jeffrey J. Tasca
AMEC
285 Davidson Avenue
Somerset, NJ 08873

Suite 100

Fax: (212) 227-5230

Phone: 732-302-9500

Project: WTC

Customer ID: OGDE54
Customer PO: 1-7918-0000-0200
Received: 12/04/01 11:08 AM

EMSL Order: 040118203

EMSL Project ID:

Analysis Date: 12/4/01

Asbestos Analysis of Bulk Materials by PLM via the NY State ELAP 198.1 Method

Sample	Location	Appearance	Treatment	Non-Asbestos		Asbestos
				% Fibrous	% Non-Fibrous	% Type
WTC-01 040118203-0001	WTC BLDG. NO. 6	Brown/White Fibrous Homogeneous	Teased	80.00% Min. Wool	20.00% Non-fibrous (other)	<1% Chrysotile
WTC-02 040118203-0002	WTC BLDG. NO. 6	Brown/White Fibrous Homogeneous	Teased	70.00% Min. Wool	30.00% Non-fibrous (other)	<1% Chrysotile
WTC-03 040118203-0003	WTC BLDG. NO. 6	Gray/White Fibrous Homogeneous	Teased	80.00% Min. Wool	19.50% Non-fibrous (other)	0.50% Chrysotile
WTC-04 040118203-0004	WTC BLDG. NO. 1	Brown Fibrous Homogeneous	Teased	80.00% Min. Wool	20.00% Non-fibrous (other)	<1% Chrysotile
WTC-05 040118203-0005	WTC BLDG. NO. 1	Brown/White Fibrous Homogeneous	Teased	80.00% Min. Wool	19.50% Non-fibrous (other)	0.50% Chrysotile
WTC-06 040118203-0006	WTC BLDG. NO. 1	Brown/White Fibrous Homogeneous	Teased	80.00% Min. Wool	20.00% Non-fibrous (other)	<1% Chrysotile
WTC-07 040118203-0007	WTC BLDG. NO. 1	Brown/White Fibrous Homogeneous	Teased	30.00% Cellulose 20.00% Min. Wool	49.25% Non-fibrous (other)	0.75% Chrysotile

Dave Poitres

Analyst

Stephen Siegel
Stephen Siegel, CH
or other approved signatory

PLM has been known to miss asbestos in a small percentage of samples which contain asbestos. Negative PLM results cannot be guaranteed. Samples reported as <1% or none detected should be tested with TEM. The above test/report relates only to the items tested. This report may not be reproduced, except in full, without written approval by EMSL Analytical, Inc. The above test must not be used by the client to claim product endorsement by NVLAP nor any agency of the United States Government.

PLM Point Count-1