

12/24/2001 14:21 2124778941

H A BADER

PAGE 03

New York Lab

307 West 38th Street, New York, NY 10018

Phone: 212-290-0051 Fax: 212-290-0050 Email:

EMSL

Attn: H.A. Bader Consultants
88 Bleecker St
Suite 4E
New York, NY 10012
Fax: (212) 477-8941 Phone: 212-476-4122
Project: DC 37 128 Barclay St. NY NY

Customer ID: HAB50
Customer PO:
Received: 12/18/01 8:44 PM
EMSL Order: 030109956
EMSL Project ID:
Analysis Date: 12/19/2001

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by
EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structure 0.3µ - 5µ ≥ 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
2/17/01 5-01 030109956-0001	1800.00	0.0500	0	None Detected		0.0043	<20.00 <0.0043	
2/17/01 5-02 030109956-0002	1820.00	0.0500	0	None Detected		0.0042	<20.00 <0.0042	
2/17/01 5-03 030109956-0003	1820.00	0.0500	0	None Detected		0.0042	<20.00 <0.0042	

Emil Bader

George William (3)

Laboratory Manager
or other approved signatory

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by EMSL. This report must not be used to claim product endorsement by NVLAP or any agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analyst accuracy and precision) is available upon request.

Accredited for NVLAP PLANTEM #101046-B, NY State ELAP #11506

TEM/HERA-1

1