

Jul-17-02 12:58P

212 949 1273

P.06

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 7/17/02 7:40:00 PM
 ATC Group #: 8518
 Analysis Date: 7/17/02

Fax: (212) 922-0630 Phone: (212) 922-0077
 Project: 5 Beekman Street

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8518 -1	1680.00	0.0562	0	None Detected	0	0.0041	<17.79	<0.0041	
02 8518 -2	1680.00	0.0562	0	None Detected	0	0.0041	<17.79	<0.0041	
03 8518 -3	1680.00	0.0562	0	None Detected	0	0.0041	<17.79	<0.0041	
04 8518 -4	1680.00	0.0562	0	None Detected	0	0.0041	<17.79	<0.0041	
05 8518 -5	1680.00	0.0562	0	None Detected	0	0.0041	<17.79	<0.0041	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM7EM #101167-0, NY State ELAP #10879

Page 1 of 1

CITY_21MC100_002941807