

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/10/02

8:30:00 AM

ATC Group #: 8431

Analysis Date: 7/10/02

Project: NYC DEP, W&P# 1079.01.02

176 Broadway

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (fS/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(fS/mm²)	(fS/cc)	
01 8431 -1	1530.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045	
02 8431 -2	1530.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045	
03 8431 -3	1530.00	0.0562	0	CHRYSTILE	2	0	0.0045	35.59	0.0090	
04 8431 -4	1530.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045	
05 8431 -5	1530.00	0.0562	0	None Detected	0	0	0.0045	<17.79	<0.0045	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NYLAP PLWTEM #101187-0, NY State ELAP #10878

Page 1 of 1

JUL-10-2002 15:02

P.05

CITY_21MC100_003879136