

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02

176 Broadway, Roof

Received: 7/12/02

8:30:00 AM

ATC Group #: 8456

Analysis Date: 7/12/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	(S/cc)	Notes
01 8456 -1	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
02 8456 -2	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
03 8456 -3	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
04 8456 -4	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048
05 8456 -5	1800.00	0.0450	0	None Detected	0	0	0.0048	<22.24	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLW/TEM #101187-0, NY State ELAP #10879