NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers , P.C.
228 E. 45th Street
New York NY 10017
Fax: (212) 922-0630 **Phone:** (212) 922-0077
Project: NYC DEP, W&P# 1079.01.02
145 Chambers Street, Roof

Received: 7/12/02 4:15:00 PM
ATC Group #: 8472
Analysis Date: 7/13/88

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5	# Structures 5μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
01 8472 -1	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
02 8472 -2	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
03 8472 -3	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
04 8472 -4	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	
05 8472 -5	1300.00	0.0674	0	None Detected	0	0	0.0044	<14.83	<0.0044	

MARK PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10878

CITY_21MC100_002942848

NYC-WTC_000186772