

Attn: Mr. Fabio Pedone
 Warren & Panzer Engineers, P.C.
 228 E. 45th Street
 New York NY 10017

Received: 6/16/02 6:00:00 PM
 ATC Group #: 8141
 Analysis Date: 6/17/02

Fax: (212) 922-0630 Phone: (212) 922-0077


Project: NYC-DEP W & P File #: 1079.01.02
 28 Trinity Pl. NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area		Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
		Analyzed				0.5µ-3 µ	5µ		(S/mm ²)	(S/cc)	
19 8141 -8	1500.00	0.0562	0	None Detected	0	0	0	0.0046	<17.79	<0.0046	
20 8141 -9	1500.00	0.0562	0	None Detected	0	0	0	0.0046	<17.79	<0.0046	

MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101187-0, NY State ELAP #10879