

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280 Fax: (212) 353-8306



Attn: Mr. Fabio Pedone
Warren & Panzer Engineers, P.C.
228 E. 45th Street
New York NY 10017

Received: 6/29/02 5:00:00 PM
ATC Group #: 8334
Analysis Date: 6/30/02

Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC-DEP W & P File #: 1079.01.02
5-27 Dutch Street, NY NY, East Facade Bldg

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/min²)	Notes
03 8334 -1	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
05 8334 -2	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
06 8334 -3	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048
07 8334 -4	1440.00	0.0562	0	None Detected	0	0.0048	<17.79	<0.0048

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/min². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 1

CITY_21MC100_002950168

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

8334

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

24 hr⁺/a 12 hr⁺/a 6 hr⁺/a 3 hr⁺/a Immediate ⁺/a

P.O. _____

CLIENT: N.Y.C.D.E.P.W&P FILE #: 1079-01-02LABORATORY: ATC ENV. CORP.CONTACT: MIKE NOLANPROJECT: 5-27 DUTCH STREET N.Y.C.ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL IILOCATION: EAST FACADE BLDG.TECHNICIAN: LAURENCE BAER

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	STOP	ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb./cc.)
-01	FIELD Blank	1	—	—	—	0902	—	—	—	—
-02	FIELD Blank	1	—	—	—	0903	—	—	—	—
-03	CHEM. ROOM DECON	3	02	4.0	4.0	0905	1505	360	—	—
-04	DUTCH ST. SOUTH	3	11	4.0	4.0	0907	FIELD VOID	—	—	JS
-05	DUTCH ST. MID. SOUTH	3	27	4.0	4.0	0910	1510	360	—	—
-06	DUTCH ST. BKT. 27 ENT.	3	07	4.0	4.0	0913	1513	360	—	—
-07	DUTCH ST. NORTH STATION	3	05	4.0	4.0	0915	1515	360	—	—
-08	CAPPED Blank	1	—	—	—	—	—	—	—	—
-09	DUTCH STREET SOUTH	3	11	10.0	10.0	1320	1520	—	—	INSUFFICIENT VOLUME

COMMENTS:

SAMPLE BY: LAURENCE BAER DATE: 6/29/02
SIGNATURE: Laurence Baer Saturday
RELEASED BY: LAURENCE BAER DATE: 6/29/02
SIGNATURE: Laurence Baer Saturday
RECEIVED BY: _____ DATE: 6/29/02
SIGNATURE: H. Gray

SAMPLE TYPE CODES

- | | |
|------------------------------|-------------------------------|
| 1 - Blank | 5 - Final Clearance (inside) |
| 2 - Pre-Abatement | 6 - Final Clearance (outside) |
| 3 - During Abatement | 7 - Personal |
| 4 - During Glove Bag Removal | 8 - Background |

SEE REVERSE SIDE FOR ANALYSIS INFORMATION