

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Fabio Pedone

Warren & Panzer Engineers, P.C.

228 E. 45th Street

New York

NY 10017

Fax: (212) 922-0630

Phone: (212) 922-0077

Received: 7/20/02

5:00:00 PM

ATC Group #: 8551

Analysis Date: 7/21/02

Project: NYC DEP, W&P# 1079.01.02

110 Liberty Street, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ²)	Notes
DE01 8551 -1	1575.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043
DE02 8551 -2	1575.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043
DE03 8551 -3	1575.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043
DE04 8551 -4	1575.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043
DE05 8551 -5	1575.00	0.0562	0	None Detected	0	0.0043	<17.79	<0.0043

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-C, NY State ELAP #10879

Page 1 of 1

14

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

PAGE 1 OF 1

P.O. _____

8557
CLIENT: NYC DEP
PROJECT: 110 Liberty St NYC
LOCATION: FACADE

W&P FILE #: 1079-01-02
LABORATORY: A.T.C.
ANALYSIS METHOD: PCM TEM TEM
circle one 7400 AHERA EPA LEVEL II
TECHNICIAN: DIP0

CONTACT: MICHAEL NOLAN
LLW#: _____
SCA JOB#: _____

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START STOP	TIME ON OFF	TOTAL TIME	VOLUME (liters)	CONCENTR. (lb/sec)
DE01	BY DECON	3		05 05	1015 1530	315	1575	
DE02	INA Right side of INA	3		05 05	1016 1531	315	1575	
DE03	✓ 1 st Middle ✓	3		05 05	1017 1532	315	1575	
DE04	✓ 2 nd Middle ✓	3		05 05	1018 1533	315	1575	
DE05	✓ Left Side ✓	3		05 05	1020 1535	315	1575	
DE06	Field Blank	1		— —	0 0	0	0	
DE07	✓	1		— —	0 0	0	0	
DE08	Sealed Blank	1		— —	0 0	0	0	

COMMENTS:

SAMPLE BY: DIP0 ELEMO DATE: 7/20/02
SIGNATURE: DIP0
RELEASED BY: DIP0 ELEMO DATE: 7/20/02
SIGNATURE: DIP0
RECEIVED BY: A.T.C. DATE: 07/20/02
SIGNATURE: M. G. 17:00

SAMPLE TYPE CODES	
1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION