NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Fabio Pedone
Warren & Panzer Engineers , P.C.
228 E. 45th Street
New York NY 10017
Fax: (212) 922-0630 Phone: (212) 922-0077

Project: NYC DEP, W&P# 1079.01.02
110 Liberty Street, New York, NY

Received: 7/22/02 8:00:00 AM
ATC Group #: 8571
Analysis Date: 7/22/02

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5	# Structures 5µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm²)	Asbestos Concentration (S/cc)	Notes
DE01 8571 -1	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
DE02 8571 -2	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
DE03 8571 -3	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
DE04 8571 -4	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	
DE05 8571 -5	1440.00	0.0562	0	None Detected	0	0	0.0048	<17.79	<0.0048	

ROMAN PEYSAKHOV
Analyzed by:

MICHAEL A. GORYCKI, Ph.D.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependant on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysts' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_21MC100_002950262

NYC-WTC_000186820

NYC-WTC_000186821

228 East 45th Street
New York, NY 10017
(212) 922-0077
Fax (212) 922-0630

WARREN & PANZER ENGINEERS, P. C.

AIR MONITORING LOG SHEET/CHAIN-OF-CUSTODY FORM

24 hr+/a 12 hr+/a 6 hr+/a 3 hr+/a Immediate +/a

P.O. _____

CLIENT: NYC DEP
PROJECT: 110 Liberty St NY
LOCATION: Facade (corner 113-117 Cedar St)
8571

W&P FILE #: 1079-01-02
LABORATORY: A-T-C
ANALYSIS METHOD: PCM 7400 / TEM AHERA (circle one) / TEM EPA LEVEL II
TECHNICIAN: DIPO

CONTACT: MICHAEL NOLAN
LLW#:
SCA JOB#:

SAMPLE NUMBER	SAMPLE DESCRIPTION/LOCATION	SAMPLE TYPE	PUMP #	FLOWRATE START	FLOWRATE STOP	TIME ON	TIME OFF	TOTAL TIME	VOLUME (liters)	CONCENTR (fib./cc.)
DE01	By DeCon	3		08	08	1015	1315	180	1440	
DE02	WA Right Side of WA	3		08	08	1016	1316	180	1440	
DE03	" 1st Middle " "	3		08	08	1017	1317	180	1440	
DE04	" 2ND Middle " "	3		08	08	1018	1318	180	1440	
DE05	" Left Side " WA	3		08	08	1020	1320	180	1440	
DE06	Field Blank	1		—	—	0	0	0	0	
DE07	" "	1		—	—	0	0	0	0	
DE08	Sealed Blank	1		—	—	0	0	0	0	

COMMENTS:

SAMPLE BY: DIPO ELOMO DATE: 7/21/02
SIGNATURE: DIPO
RELEASED BY: DIPO ELOMO DATE: 7/21/02
SIGNATURE: DIPO
RECEIVED BY: ATC DATE: 7/22/02
SIGNATURE: JD Sam

SAMPLE TYPE CODES

1 - Blank	5 - Final Clearance (inside)
2 - Pre-Abatement	6 - Final Clearance (outside)
3 - During Abatement	7 - Personal
4 - During Glove Bag Removal	8 - Background

SEE REVERSE SIDE FOR ANALYSIS INFORMATION

CITY_21MC100_002950263

NYC 9/11 Public Portal Document

NYC 9/11 Public Portal Document

ATC Associates Inc.
104 East 25 Street
New York, NY 10010
TEL: (212) 353-8280 FAX: (212) 353-8306

FACSIMILE TELECOPY TRANSMISSION

To:	Mr. Fabio Pedone Warren & Panzer Engineers, P.C.	**From:**	ROMAN PEVSAKHOV
		ATC Group #:	8571
Fax #:	(212) 922-0630	**Client Project:**	NYC DEP, W&P# 1079.01.02 110 Liberty Street, New York, NY
Date:	Monday, July 22, 2002		
Time:	3:08:13 PM		
Comments:		**Number of Pages:**	3 (including cover page)

NYC-WTC_000186822