

DEP

ASBESTOS ANALYTICAL REPORT

**ASBESTOS CONTROL PROGRAM LABORATORY
96-05 HORACE HARDING EXPRESSWAY
CORONA, NEW YORK 11368
(718) 595-6309 FAX# (718) 595-6307**

ELAP # 11045

**TEST METHODS : 1) 40 CFR Part 763, Subpart F, App. A
2) Polarized Light Microscopy plus Stratified Point-Counting Method
3) EPA/600/R-93/116**

Incident #: TRU0273MN03
Inspector : P. THEODORELLYS
Premise : 114 LIBERTY STREET
Boro : Manhattan
Analyst : G. ANAKHU

Date Collected: 03/17/03
Received: 03/17/03
Analyzed: 03/18/03

Client #:

DEP Sample #: 30317/A019015

Laboratory #: 30317/347

Location Sampled: 9TH FL BEAM

Color: GREY

Homogenous: Yes


Asbestos Present: No

Results (%)

Cellulose 1
Fibrous glass 42
Silicates 5
Matrix 52

Comments:

Reviewed by:


Laboratory Director

This test report may not be reproduced except with the written approval of this laboratory. The test report relates only to the item(s) listed and does not represent a product endorsement by NVLAP or any other U.S. Government agency.