NYC 9/11 Public Portal Document

Attn: Mr. Andrew Gasparro
JLC Environmental Consultants, INC.

Received: 4/4/03 11:30:00 PM
ATC Group #: 9626
Analysis Date: 4/5/03

Fax: (212) 420-6092 **Phone:** (212) 420-8119

Project: DEP Project #: 03-2744
114 Liberty Street, New York, NY

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volum*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5µ-5*	*5µ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
8 *9626 -8*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
9 *9626 -9*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
10 *9626 -10*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
11 *9626 -11*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
12 *9626 -12*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	

MARK PEYSAKHOV
Analyzed by:

MILENA LOWD.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

CITY_DEP_WORBY_CANNATA_SUBP_000005999

NYC-WTC_000186846

NYC 9/11 Public Portal Document

ATC Associates
104 East 25 Street, New York, NY 10010
Phone: (212) 353-8280 Fax: (212) 353-8306

Attn: Mr. Andrew Gasparro
JLC Environmental Consultants, INC.

Received: 4/4/03 11:30:00 PM
ATC Group #: 9626
Analysis Date: 4/5/03

Fax: (212) 420-6092 **Phone:** (212) 420-8119
Project: DEP Project #: 03-2744
114 Liberty Street, New York, NY

Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed by EPA 40 CFR Part 763 Final Rule (AHERA)

Sample	*Volum*	*Area Analyzed*	*Non Asb*	*Asbestos Type(s)*	*# Structures 0.5µ-5*	*5µ*	*Analytical Sensitivity (S/cc)*	*Asbestos Concentration (S/mm²)*	*(S/cc)*	*Notes*
1 *9626 -1*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
2 *9626 -2*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
3 *9626 -3*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
4 *9626 -4*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
5 *9626 -5*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
6 *9626 -6*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	
7 *9626 -7*	3643.00	0.2473	0	None Detected	0	0	0.0004	<4.04	<0.0004	

MARK PEYSAKHOV
Analyzed by:

MILENA LOWD.
Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Saturday, April 05, 2003

CITY_DEP_WORBY_CANNATA_SUBP_000006000

NYC-WTC_000186847