

P.S. / I.S. 89M - AMBIENT AREA AIR TEM, SETTLED DUST & BULK SAMPLE RESULTS					
	TEM Ambient Air Sampling (Structure / mm ²)		Settled Dust Bulk sampling for Asbestos		Bulk and Magic scotch tape sampling for asbestos (Playground and soil areas)
Date	# of Sample	Results of TEM Asbestos Analysis (structure/mm ²)	# of Sample	Results of Settled Dust Bulk Sample for Asbestos	
11/03/01			39	Trace or Non Detected	33 Bulk Samples = Trace or Non Detected 29 Scotch Magic Tape Samples = Trace or Non Detected
			6	>1% Asbestos (settled dust in soil found outside the building)	
11/05/01	25	One structure (22.24 Structure/mm ²) was found in each of the following locations: Room 502, room 402, 14 Floor corridor, and corridor adj. to room 143.			
12/11/01			6	2 samples = Trace amount of Asbestos 4 Samples = No Asbestos Fibers found	
01/11/02					11 bulk samples = Non Detected 5 Scotch Magic Tape Sample = Non Detected
01/12/02	4	No Structures Detected			
01/16/02	12	One structure (22.24 Structure/mm ²) found in one sample in the north playground and another structure (22.24 structure/mm ²) found on the 3 rd floor hallway southside.			
01/17/02	12	No Structures Detected			
01/18/02	12	No Structures Detected			
01/19/02	6	No Structures Detected			
01/21/02	11	No Structures Detected			
01/22/02	16	No Structures Detected			
01/24/02	15	No Structures Detected			
01/25/02	16	One structure (22.24 Structure/mm ²) found in one sample in the cafet.			
01/26/02	16	No Structures Detected			
01/27/02	16	One structure (22.24 Structure/mm ²) found in one sample on the roof.			
01/28/02	16	No Structures Detected			
01/29/02	16	No Structures Detected			
01/30/02	16	No Structures Detected			
01/31/02	16	No Structures Detected			
02/01/02	16	No Structures Detected			
02/02/02	15	No Structures Detected			
02/03/02	16	No Structures Detected			
2/04/02	16	No Structures Detected			
2/05/02	16	No Structures Detected			
2/06/02	16	No Structures Detected			