

Tel. (718) 784-7490
Fax (718) 784-4085

CLIENT: WARREN & PANZER	DATE: 9/21/02
PROJECT: NYCDOP/60 WILLIAMS ST.	ANALYST: E.S.
BATCH #: 102-09-073	CLIENT ID #: 03
SAMPLE ID #: 102-09-073-2437	VOLUME (l): 1800
G.O. AREA (mm ²): 0.013838	GO's TO ANALYZE: 4
MAGNIFICATION: 19K	ACC. VOLTAGE (KeV): 100
INSTRUMENT: JEOL 100CX II	FILTER AREA (mm ²): 385
ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40 CFR, PART 763, APPENDIX A TO SUBPART E	

[illegible]

Analytical Sensitivity (str/cm ²):	0.0039	Eucentricity check:	
Concentration (str/cm ²):	0.0039	*Grid acceptance criteria check:	(A)..... (B).....
Concentration (str/mm ²):	18.107	**CHR. # STRUCT.:	F 6 M 0 C 0 B 0
Number of Asbestos Structures:	0.5 ≤ S < 5 μm 0/..	**AMPH. # STRUCT.:	F M C B
	S ≥ 5 μm 0...	Specify AMPH. Type:	AM. ACT. TRE.
Number of Non-asbestos Structures:	 0/.....	CRO. ANTH.	

** CHR.=chrysotile, AMPH.=amphibole, AM.=amosite, ACT.=actinolite, TRE.=tremolite, CRO.=crocidolite, ANTH.=anthophyllite.