

ENVIRONMENTAL SERVICES INC.

Tel. (718) 784-7490
Fax (718) 784-4086

CLIENT: WARREN & PANZER	DATE: 11/14/02
PROJECT: MCDEP/150 Williams str	ANALYST: ES
BATCH #: T02-11-069	CLIENT ID #: 03
SAMPLE ID #: T02-11-069-4052	VOLUME (lt): 1800
G.O. AREA (mm ²): 0.013433	GO's TO ANALYZE: 4
MAGNIFICATION: 19K	ACC. VOLTAGE (KeV): 100
INSTRUMENT: JEOL 100CX II	FILTER AREA (mm ²): 385
ANALYTICAL METHODOLOGY: EPA FEDERAL REGISTER, VOL. 52, No 210, OCT. 30, 1987, #40 CFR, PART 763, APPENDIX A TO SUBPART E	

[illegible]

Analytical Sensitivity (str/cm ³):	0.0040	Eucentricity check :	
Concentration (str/cm ³) :	<0.0040	*Grid acceptance criteria check :	(A)..... (B).....
Concentration (str/mm ²):	<18.61	**CHR. # STRUCT. :	F M C B
Number of Asbestos Structures :	0.5 ≤ S < 5 μm 0..	**AMPH. # STRUCT.:	F M C B
	S ≥ 5 μm 0..	Specify AMPH. Type :	AM. ACT. TRE.
Number of Non-asbestos Structures:	 0..	CRO. ANTH.	

** CHR.=chrysotile, AMFH=amphibole, AM.=amosite, ACT.=actinolite, TRE=tremolite, CRO.=crocidolite, ANTH=anthophyllite