



**Warren & Panzer Engineers, P.C.**  
228 East 45th Street  
New York, New York 10017  
Tel. (212) 922-0077  
Fax (212) 922-0630

July 1, 2002

Mr. Leonard G. Atteloney  
**New York City Department of Environmental Protection**  
96-05 Horace Harding Expressway  
Corona, NY 11368

**Re: Final Clearance TEM Air Sample Results**

W&P File #: 1079.01.02

Dear Mr. Atteloney:

On June 8, 2002, a roofing-cleaning project was completed at the building located at 92 Chambers Street. Transmission Electron Microscopy air samples were collected at the completion of the abatement work. Final clearance air samples collected met the clearance criteria of less than 70 Structures per square millimeter set forth by the NYS Department of Labor Industrial Code Rule 56 and the NYC Department of Environmental Protection Title 15, Chapter 1 Asbestos Rules and Regulations, and this area can now be re-occupied.

Along with this correspondence, I have enclosed a copy of the final visual inspection checklist. If you have any questions or should you need additional information, please contact me at (212) 922-0077.

Sincerely,

**WARREN & PANZER ENGINEERS, P.C.**

A handwritten signature in black ink, appearing to read 'Michael R. Nolan', is written over a horizontal line.

Michael R. Nolan  
Senior Project Manager

cc: Krish Radhakrishnan, PE  
Attachment(s)

*A Member of  
The Warren & Panzer Group*

CITY\_21MC100\_002965006