



Warren & Panzer Engineers, P.C.

228 East 45th Street

New York, New York 10017

Tel. (212) 922-0077

Fax (212) 922-0630

April 1, 2003

Mr. Leonard G. Atteloney

New York City Department of Environmental Protection

96-05 Horace Harding Expressway

Corona, NY 11368

Re: Final Clearance TEM Air Sample Results

W&P File #: 1079.01.02

Dear Mr. Atteloney:

On September 15, 2002, a roofing/façade cleaning project was completed at the building located at 12-16 Vessey Street. Transmission Electron Microscopy air samples were collected at the completion of the abatement work. Final clearance air samples collected met the clearance criteria of less than 70 Structures per square millimeter set forth by the NYS Department of Labor Industrial Code Rule 56 and the NYC Department of Environmental Protection Title 15, Chapter 1 Asbestos Rules and Regulations, and this area can now be re-occupied.

Along with this correspondence, I have enclosed a copy of the final visual inspection checklist. If you have any questions or should you need additional information, please contact me at (212) 922-0077.

Sincerely,

WARREN & PANZER ENGINEERS, P.C.

A handwritten signature in black ink, appearing to read 'Michael R. Nolan', is written over a horizontal line.

Michael R. Nolan

Senior Project Manager

cc: Krish Radhakrishnan, PE

Attachment(s)

*A Member of
The Warren & Panzer Group*

CITY_21MC100_002965145