

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

TIME 1100

LOCATION PS150 M DATE 2/6/02 PROJECT NO. 19125-289

Location	Occup. (#)	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Outside Main Entrance	OUTDOORS	42.7	14.1	470	0	41	0
SE Corner		43.1	14.4	479	0	40	0
East side		43.5	15.0	485	0	42	0
West side		40.5	15.5	490	1	38	0
North side.		42.6	15.9	499	0	38	0
Guidance Rm.	5	73.1	19.3	801	0	30	0
Main Lobby Area	10	74.0	19.0	654	0	28	0
Ed's Room	10	72.7	20.4	764	0	31	0
Slop Sink (HALL)		74.7	17.5	546	0	34	0
Mucic Rm.	24	74.6	19.4	1101	0	37	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: Working in the Courtyard (construction)

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 2/6/02

CITY_21MC100_002954095

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4

TIME 11:30

LOCATION PS150 M


DATE 2/6/02

PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOC (ppm)
404		75.8	18.1	771	0	30	0
403 (Hall)		76.3	17.4	618	0	32	0
403		76.3	17.7	649	0	34	0
402	27	77.5	19.3	793	0	28	0
401	29	77.6	17.6	997	0	27	0
(3rd Fl) West Stairs	—	76.3	15.7	650	0	31	0
501	20	74.3	16.4	821	0	24	0
502	17	74.4	17.1	788	0	28	0
503	22	74.4	18.9	1009	0	26	0
504	4	74.5	20.3	911	0	23	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 2/6/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1500LOCATION PS150 MDATE 2/6/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Outside Main Entrance		42.0	29.9	470	0	36	0
outside Northside		42.3	29.1	479	0	38	0
outside Westside		40.1	30.3	487	1	30	0
outside East Side.	OUTSIDE	41.3	30.5	500	1	34	0
SE Corner		43.1	29.7	509	1	30	0
Main Office	3	73.0	17.9	799	0	21	0
Principal Office	3	73.5	17.5	809	0	20	0
Nurse Rm	2	74.0	17.0	851	0	18	0
Speech Rm	1	73.9	16.9	756	0	16	0
Kitchen		75.0	16.1	699	0	20	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____ Date: 2/6/02

CITY_21MC100_002954097

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1530LOCATION PS150 MDATE 2/6/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
404		74.6	19.1	769	0	28	0
403		76.0	17.1	700	0	20	0
402		76.1	16.9	691	0	24	0
401		76.3	16.5	809	0	30	0
401 (Hall)		76.4	15.7	621	0	29	0
501		74.0	16.8	771	0	20	0
502		74.6	17.3	788	0	18	0
503		74.4	18.0	890	0	16	0
504		75.1	20.0	709	0	20	0
504 (Hall)		76.3	15.9	635	0	25	0
Guideline levels ASHRAE/AIHA/EPA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 2/6/02

CITY_21MC100_002954098