

ATC ASSOCIATES, INC. INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

TIME 1100

LOCATION PS150 M

DATE 2/8/02

PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
Outside Main Door		55.1	15.9	460	0	28	0
Outside North Side		54.8	16.2	463	0	40	0
Outside East Side		54.5	16.4	460	0	39	0
Outside West Side		55.0	16.6	462	0	36	0
Outside SE Corner		55.5	16.6	461	0	31	0
Ed's Room	8	82.2	17.7	675	0	22	0
Resource Room	2	81.9	16.6	745	0	24	0
Nurse Rm.	2	81.4	16.1	617	0	29	0
Window 1,2 OPEN. Kitchen	3	79.5	14.0	633	0	27	0
Music Room.	16	76.0	15.7	643	0	34	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: Working in the Courtyard

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jim Chan Date: 2/8/02

CITY_21MC100_002954113

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1130LOCATION P5150 M DATE 2/8/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
404	26	77.4	18.4	907	0	18	0
404(HALL)	—	77.9	18.4	830	0	23	0
403	3	77.9	18.8	806	0	18	0
402	—	79.6	18.4	619	0	22	0
401	30	79.9	21.3	1350	0	16	0
501	26	77.7	20.7	879	0	30	0
502	21	76.9	19.8	831	0	17	0
W/n #3 OPEN 503	3	77.2	21.4	1018	0	14	0
504	20	76.0	24.9	1259	0	24	0
504(HALL)	—	76.1	22.2	849	0	22	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jim Choy Date: 2/8/02

CITY_21MC100_002954114

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1500LOCATION PS150 M DATE 2/8/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate Matter (µg/m³)	TVOCs (ppm)
Outside Main Entrance		54.0	16.0	480	0	20	0
Outside North		53.8	15.5	483	0	18	0
Outside East		53.6	15.3	481	0	24	0
Outside West		54.1	15.0	478	0	21	0
SE Corner Outside		54.5	15.8	483	0	26	0
Ed's Room		79.9	17.5	651	0	20	0
Main OFFICE		80.1	16.9	640	0	18	0
Principal OFFICE		79.8	16.2	638	0	20	0
Music Room		76.6	16.0	640	0	24	0
Hall by East Stair		75.9	15.9	643	0	21	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jiri Chy Date: 2/8/02

CITY_21MC100_002954115

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 15:45LOCATION PS150 MDATE 2/8/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
504		76.4	18.0	781	0	16	0
503		77.1	19.1	709	0	20	0
502		77.1	20.1	763	0	20	0
501		79.6	19.3	751	0	23	0
503 (Hall)		76.1	21.0	690	0	18	0
404		77.4	19.8	701	0	25	0
403		76.9	19.5	691	0	16	0
402		76.7	19.7	610	0	13	0
401		77.3	20.1	765	0	20	0
403 (Hall)		76.3	21.3	688	0	18	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 2/8/02