

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

TIME 1400LOCATION PS150 MDATE 2/27/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
Outside South Side		42.5	47.0	485	0	26	0
Outside SE Corner		42.3	47.3	482	0	28	0
Outside East Side		42.0	47.9	490	0	30	0
Top Stairs Outside East Side		41.9	48.3	488	0	28	0
Outside NE Corner		41.5	48.6	484	0	31	0
Outside North Side		41.3	49.6	480	0	28	0
Top Stairs Outside North Side		41.0	49.9	483	0	30	0
Outside West Side		40.8	50.3	486	0	28	0
Outside NW Corner		40.5	50.7	477	0	26	0
Outside Main Entrance		40.6	51.0	473	0	27	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: NO Work in Courtyard

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 2/27/02

CITY_21MC100_002954176

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1430LOCATION PS150 MDATE 2/27/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer		69.3	38.3	799	0	20	0
Main Desk		70.3	36.8	780	0	21	0
Main Lobby Area		70.7	28.5	815	0	15	0
Main Office		72.2	37.1	790	0	19	0
Guidance Rm.		73.5	33.7	784	0	13	0
Hall by Rest Rms.		74.6	32.0	547	0	17	0
Hall by Slop Sink		74.8	39.0	516	0	16	0
Nurse Rm.		74.8	29.1	538	0	21	0
Resource Rm.	5	75.0	29.2	633	0	17	0
Kitchen Area		75.4	28.4	620	0	17	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 2/27/02

CITY_21MC100_002954177

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4

TIME 1500

LOCATION PS150 M


DATE 2/27/02

PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Muscle Rm.	—	75.1	27.8	610	0	20	0
Ed's Room	1	71.0	29.0	780	0	17	0
Hall by East Stair	—	75.2	26.3	546	0	13	0
404	—	73.3	25.5	780	0	19	0
403	20	73.6	24.5	799	0	17	0
402	18	73.8	23.0	789	0	16	0
401	10	74.0	24.6	804	0	19	0
Hall by Shop Sink		75.0	26.0	690	0	21	0
Hall by Boys Rm		75.1	26.3	681	0	20	0
Hall by Girls Rm		75.0	26.5	670	0	16	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature:  Date: 2/27/02

CITY_21MC100_002954178

ATC ASSOCIATES, INC.


Page 4 of 4TIME 1535

INDOOR AIR QUALITY FIELD REPORT

LOCATION PS150 M DATE 2/27/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOC (ppb)
404 (Hall)		74.3	26.0	666	0	19	0
Hall by West Stairs		74.0	26.3	670	0	16	0
501	15	75.2	26.8	979	0	16	0
502	20	75.4	27.0	1009	0	18	0
503	10	75.0	29.1	801	0	18	0
504	19	75.3	28.5	983	0	20	0
Hall by East Stairs		74.9	26.5	622	0	12	0
Hall by Rest Rms		74.5	26.7	709	0	14	0
504 (Hall)		75.0	26.0	715	0	13	0
Hall by S/op Sink		75.3	26.7	729	0	15	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☒ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 2/27/02