

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

TIME 1410

LOCATION PS150 M DATE 3/26/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m³)	TVOC (ppm)
South Side		43.0	34.6	385	0	39	0
SE Corner		42.8	35.0	390	0	36	0
East Side		42.2	35.3	399	0	30	0
NE Corner		41.8	36.0	403	0	32	0
North Side		41.6	36.8	408	0	35	0
NW Corner		41.0	37.1	415	0	30	0
West Side		40.6	39.0	419	0	29	0
North (top stairs)		40.5	40.1	423	0	38	0
East (top stairs)		40.3	42.3	430	0	39	0
Main Entrance		40.0	44.0	432	0	40	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m³ 24-hour average	1 ppm

Comments: Working in Courtyard

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: [Signature] Date: 3/26/02


CITY_21MC100_002954203

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1430LOCATION PS150 M DATE 3/26/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Main Foyer	1	69.9	38.1	528	0	25	0
Hall by West Stairs		70.0	38.1	535	0	27	0
Main Desk		69.4	46.1	547	0	25	0
Ed's Rm.	4	70.6	40.1	575	0	21	0
Main Lobby		71.2	38.6	555	0	25	0
Main Office	2	71.5	37.6	606	0	22	0
(Main) Principal	1	72.1	36.2	630	0	22	0
Guidance Rm	5	72.8	34.4	591	0	24	0
Hall by Boys Rm		74.0	33.8	478	0	28	0
Hall by Girls Rm		74.2	33.5	477	0	31	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature:  Date: 3/26/02

CITY_21MC100_002954204

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1500LOCATION PS150 MDATE 3/26/02 PROJECT NO. 19125-289

Location	Occup	Temperature (°F)	Relative Humidity(%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
Hall by Slop Sink		74.1	33.7	488	0	33	0
Resource Rm	6	74.5	39.1	561	0	35	0
Nurse Rm		75.3	32.7	622	0	33	0
Kitchen		76.8	30.2	587	0	34	0
Music Rm		77.6	30.4	765	0	28	0
Hall by East Stairs.		77.4	28.3	546	0	27	0
404		77.6	27.9	528	0	24	0
404 (Hall)		77.7	27.9	540	0	25	0
403		77.7	27.7	642	0	27	0
Hall by Rest Rm		77.4	28.0	514	0	26	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: _____ Date: 3/26/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1535LOCATION PS150 MDATE 3/26/02 PROJECT NO. 19125-289

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Hall by Staff Rm		77.0	28.3	590	0	25	0
Book Rm (Hall)		77.4	28.2	596	0	24	0
402		76.9	27.4	549	0	26	0
401		76.9	26.3	840	0	26	0
Hall by West Stair		77.0	28.3	591	0	24	0
501		77.3	29.1	546	0	24	0
502		77.0	28.9	550	0	22	0
503		76.8	29.3	540	0	23	0
504		76.9	28.3	563	0	23	0
504 (Hall)		76.9	28.4	580	0	24	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.Signature: Jim Chen Date: 3/26/02