

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT


Page 1 of 4TIME 1415LOCATION PS150 MDATE 3/20/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity(%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
<u>Outside</u>							
<u>South Side</u>		<u>48.6</u>	<u>47.0</u>	<u>425</u>	<u>0</u>	<u>18</u>	<u>0</u>
<u>SE Corner</u>		<u>48.1</u>	<u>47.6</u>	<u>429</u>	<u>0</u>	<u>16</u>	<u>0</u>
<u>East Side</u>		<u>48.4</u>	<u>48.1</u>	<u>436</u>	<u>0</u>	<u>16</u>	<u>0</u>
<u>NE Corner</u>		<u>48.0</u>	<u>48.8</u>	<u>441</u>	<u>0</u>	<u>15</u>	<u>0</u>
<u>North Side</u>		<u>47.8</u>	<u>49.1</u>	<u>449</u>	<u>0</u>	<u>14</u>	<u>0</u>
<u>NW Corner</u>		<u>47.2</u>	<u>50.0</u>	<u>452</u>	<u>0</u>	<u>13</u>	<u>0</u>
<u>West Side</u>		<u>47.4</u>	<u>50.5</u>	<u>457</u>	<u>0</u>	<u>15</u>	<u>0</u>
<u>North Top of Stairs</u>		<u>47.9</u>	<u>50.9</u>	<u>450</u>	<u>0</u>	<u>16</u>	<u>0</u>
<u>Main Entrance</u>		<u>47.7</u>	<u>51.3</u>	<u>446</u>	<u>0</u>	<u>15</u>	<u>0</u>
<u>East Top of Stairs</u>		<u>47.3</u>	<u>51.5</u>	<u>443</u>	<u>0</u>	<u>15</u>	<u>0</u>
<u>Guideline levels</u> ASHRAE/AHIA/EPA		<u>68 -75°F/winter</u> <u>73 -79°F/summer</u>	<u>30-60%</u>	<u>Outdoor level +</u> <u>700 ppm</u>	<u>9 ppm</u>	<u>65 ug/m³</u> <u>24-hour average</u>	<u>1 ppm</u>

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____



Date: _____

3/20/02

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4TIME 1435LOCATION PS150 M DATE 3/20/02 PROJECT NO. 19125-289

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	VOCs (ppm)
504		69.9	30.3	690	0	7	0
504 (Hall)		73.0	31.0	700	0	10	0
503		70.3	30.6	596	0	7	0
Hall by East Stairs.		73.3	31.3	719	0	9	0
Hall by Boys RM		73.4	31.6	723	0	10	0
Hall by Staff RM		73.2	31.9	729	0	8	0
502		70.9	30.9	603	0	8	0
501		71.6	31.6	610	0	10	0
Hall by West Stairs.		72.9	30.6	735	0	8	0
401		71.5	31.3	659	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: Jin Chen Date: 3/20/02

CITY_21MC100_002954240

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1500LOCATION PS150 M DATE 3/20/02 PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
401 (Hall)		73.1	31.0	701	0	10	0
402		72.9	30.3	711	0	7	0
Hall by Rest Rm		73.3	31.6	698	0	12	0
Hall by Slopsink		73.5	31.4	690	0	14	0
403		72.6	29.6	711	0	8	0
404		72.8	29.0	716	0	7	0
404 (Hall)		74.0	31.0	693	0	10	0
Hall by East Stairs		73.8	32.0	696	0	10	0
Music Room		73.1	32.3	719	0	8	0
Kitchen Area		74.6	34.6	802	0	8	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: J. Ch Date: 3/20/02

CITY_21MC100_002954241

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4

TIME 1530

LOCATION P5150 M


DATE 3/20/02

PROJECT NO. 19125-289

Location	Occupancy	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
Nurse Rm		74.6	32.0	719	0	15	0
Resource Rm		74.8	31.8	809	0	10	0
Hall by Rest Rms		73.8	31.6	701	0	10	0
Main Lobby Area		72.9	31.4	756	0	9	0
Main Office		73.6	31.0	803	0	10	0
Principal Office		72.9	30.6	810	0	12	0
Ed's Room		71.3	32.0	703	0	8	0
Main Desk		73.0	30.8	750	0	14	0
Main Foyer		72.9	31.6	691	0	18	0
Hall by Wat Stairs.		72.6	31.9	688	0	21	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/20/02

CITY_21MC100_002954242