

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 1 of 4

TIME 1200

LOCATION PS150 M


DATE 3/5/02

PROJECT NO. 19125-289

Location	Occupancy	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (µg/m³)	TVOCs (ppm)
Outside							
West Side		56.6	59.0	420	0	118	0
NW Corner		56.9	58.6	428	0	107	0
North Side		57.3	58.0	415	0	100	0
Top of Stairs North Side		56.8	57.6	416	0	114	0
Main Entrance		56.5	57.0	418	0	116	0
East Top of Stairs		56.3	56.8	416	0	115	0
East side		56.9	56.3	420	0	109	0
NE Corner		57.3	58.1	414	0	112	0
SE Corner		57.6	58.3	424	0	115	0
South Side		56.6	59.0	420	0	113	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: Working in the Courtyard

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/5/02

CITY_21MC100_002954266

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 2 of 4

TIME 1230

LOCATION PS150 M

DATE 3/6/02

PROJECT NO. 19125-289

Location	Occup	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (µg/m³)	TVOCs (ppm)
Main Foyer		69.5	50.1	565	0	77	0
Hall by West Stair		69.1	48.5	560	0	73	0
Main Desk		69.8	48.1	585	0	79	0
Main Lobby Area		70.6	47.9	603	0	79	0
Ed's Rm	9	70.8	46.8	624	0	58	0
Main Office		71.4	45.6	574	0	71	0
Principal Office		71.8	43.8	554	0	69	0
Hall Girls Rm		72.3	48.0	545	0	78	0
Hall Boys Rm		72.4	44.8	540	0	76	0
Hall by Slop sink		73.2	45.9	593	0	77	0
Guideline levels ASHRAE/AIHA/EPA		68-75°F/winter 73-79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 µg/m³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/10/02

CITY_21MC100_002954267


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 3 of 4TIME 1300LOCATION PS150 MDATE 3/15/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable particulate (ug/m ³)	TVOCs (ppm)
Resource Rm	7	73.4	45.2	688	0	79	0
Nurse Rm	1	73.8	44.6	676	0	76	0
Kitchen Area.	1	74.5	42.1	612	0	78	0
Music Rm	1	74.3	45.8	840	6	78	0
Hall by East Stairs.	—	74.3	44.0	698	0	79	0
404	21	75.2	42.6	794	0	45	0
404 (Hall)	—	75.1	40.9	511	0	71	0
403	—	74.8	40.7	597	0	68	0
Hall By Boys Rm	—	75.0	40.0	567	0	69	0
Hall by Girls Rm	—	75.1	40.6	560	0	70	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/15/02


ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

Page 4 of 4TIME 1330LOCATION PS150 MDATE 3/15/02PROJECT NO. 19125-289

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulate (ug/m ³)	TVOCs (ppm)
Hall by Staff Rm		74.6	39.5	495	0	70	0
402		74.9	38.5	540	0	72	0
401		74.5	38.0	569	0	47	0
401 (Hall)	—	74.6	37.9	491	0	69	0
501		74.8	39.6	549	0	50	0
Hall by West Stair	—	74.5	37.5	499	0	63	0
502		74.9	38.8	555	0	70	0
Hall by Rest Rm	—	74.8	38.6	509	0	67	0
503		75.6	38.0	589	0	64	0
504	—	75.3	38.3	559	0	69	0
Guideline levels ASHRAE/AIHA/EPA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:  Date: 3/15/02