



104 East 25th St., 10th Floor
New York, New York 10010
www.atc-enviro.com
212.353.8280
Fax 212.353.8306

June 10, 2002

Mr. Bernard P. Orlan
Director, Environmental Health & Safety
New York City Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101-4008

**Re: Indoor Air Quality Assessment
High School for Leadership & Public Service (M894)
90 Trinity Place
New York, New York 10006
ATC Project No. 15-19125-0290**

Dear Mr. Orlan:

ATC Associates Inc. (ATC) is pleased to provide this report of indoor air quality (IAQ) measurements collected on June 7, 2002, at the referenced school. The New York City Board of Education (BOE) requested these measurements as part of a program to determine if acceptable indoor air quality is being maintained.

SCOPE OF WORK

ATC conducted this evaluation to assess the basic parameters of temperature, relative humidity, carbon dioxide (CO₂) and carbon monoxide (CO).

Total volatile organic compounds (TVOCs) and respirable particulates were also measured.

Mariana Medinets, Environmental Technician of ATC's New York City office, conducted the assessment. ATC's findings are based on a visual inspection, real-time environmental measurements and conditions present in the school at the time of the assessment.

ATC measured temperature, relative humidity, CO₂ and CO with a Q-Trak[®] Model 8551, manufactured by TSI, Inc.

ATC measured concentrations of respirable particulates (PM_{2.5}) with a Dust-Trak[®] Aerosol Monitor Model 8520, manufactured by TSI, Inc.

ATC measured concentrations of TVOCs using a RAE Systems, Inc. MiniRAE[®] photoionization detector (PID).

The assessment was performed consistent with generally accepted indoor air quality assessment practices. As with all such assessments, there were inherent limitations created by constraints of time, operational and work practice variability, variations in indoor air quality parameters and sampling and analytical accuracy.

Mr. Bernard P. Orlan
 Indoor Air Quality Assessment
 H.S. for Leadership & Public Service (M894)

June 10, 2002
 Page 2
 ATC Project No. 15-19125-0290

The results of the sampling represent conditions found on the dates of the survey and may not represent conditions found at other times. The information presented in this report should be used by the BOE as a guide to assess the need for further improvements in current indoor air quality control activities.

EVALUATION CRITERIA

Currently, there are no regulatory standards for indoor air quality in non-industrial buildings, such as offices and schools. For the real-time data collected, ATC uses the commonly accepted guidelines cited in the following publications:

- *Ventilation for Acceptable Indoor Air Quality (ASHRAE 62-1999)*, American Society of Heating, Refrigerating, and Air-Conditioning Engineers (ASHRAE);
- *Thermal Environmental Conditions for Human Occupancy (ASHRAE 55-1992)*;
- *Industrial Hygienists Guide to Indoor Air Quality Investigations* (1993), American Industrial Hygiene Association (AIHA).

Table 1 lists target guidelines for the parameters that ATC evaluated during this investigation. Meeting one, some, or all of the listed values does not assure that acceptable indoor air quality will be achieved at all times.

TABLE 1
TARGET GUIDELINES FOR INDOOR AIR QUALITY PARAMETERS EVALUATED

Carbon Dioxide (CO ₂)	<700 parts per million (ppm) above background level	ASHRAE 62
Carbon Monoxide (CO)	9 ppm	ASHRAE 62 (adopted from USEPA NPAAQS)
Respirable Particulates (PM _{2.5})	65 micrograms per cubic meter of air (µg/m ³) 24-hour average	USEPA NPAAQS
	40 µg/m ³ 24-hour average	USEPA – Recommendation for children / sensitive individuals
Temperature	Summer: 73-79°F at 50% RH Winter: 68-75°F at 50% RH	ASHRAE 55
Relative Humidity	30 – 60 %	ASHRAE 55
Total Volatile Organic Compounds (TVOC)	1 ppm	AIHA

USEPA = United States Environmental Protection Agency
 NPAAQS = National Primary Ambient-Air Quality Standard
 AIHA = American Industrial Hygiene Association

REAL-TIME ENVIRONMENTAL MEASUREMENTS

ATC collected one hundred and forty (140) sets of real-time environmental measurements consisting of one hundred and twenty-eight (128) in the school building and twelve (12) outdoors. All fourteen floors of the school were surveyed. Field data sheets are found in the Attachment. Readings were collected in the morning and evening. The results are described below.

Temperature

Indoor dry bulb temperature measurements ranged from 71.5 to 76.8 °F. Five (5) of the indoor measurements for temperature were below and One hundred and twenty three (123) of the measurements were within the range of 73 to 79 °F (at 50 percent relative humidity) recommended by ASHRAE Standard 55-1992 during the summer season. The outdoor temperature ranged from 65.2 to 69.4 °F.

Relative Humidity

The relative humidity indoors ranged from 43.3 percent to 56.3 percent. All of the indoor measurements for relative humidity were within the ASHRAE-recommended range of 30 to 60 percent for occupant comfort. The outdoor relative humidity range was 50.1 to 66.5 percent.

Carbon Dioxide Concentration

Carbon dioxide concentrations indoors ranged from 654 ppm to 1006 ppm. All of the indoor measurements for CO₂ were below the ASHRAE Standard 62-1999 recommended maximum concentration of <700 ppm above the background level. The outdoor (background) CO₂ concentration was 686 ppm. Therefore, the maximum acceptable level of CO₂ at this location was 1386 ppm (background level + 700 ppm). Carbon dioxide measurements are used as an indicator of available outdoor air. The primary source of CO₂ indoors is occupant respiration.

Carbon Monoxide Concentration

Carbon monoxide concentrations indoors ranged from 0 ppm to 1 ppm. These concentrations were below the NPAAQS/ASHRAE guideline of 9 ppm. The outdoor CO concentrations ranged from 1 ppm to 4 ppm.

Respirable Particulates (PM_{2.5})

Respirable particulate concentrations* indoors ranged between 0 µg/m³ to 17 µg/m³ with an average 6 µg/m³. None of the indoor measurements for PM_{2.5} were above the NPAAQS of 65 µg/m³ 24-hour average concentration of particulate matter 2.5 micrometers or less in aerodynamic diameter and the USEPA recommended concentration of 40 µg/m³ for sensitive individuals such as asthmatic people and children. The outdoor respirable particulate concentrations ranged from 15 µg/m³ to 62 µg/m³ with an average of 33 µg/m³.

Mr. Bernard P. Orlan
Indoor Air Quality Assessment

June 10, 2002

Page 4

H.S. for Leadership & Public Service (M894)ATC Project No. 15-19125-0290

* The measurements made during this assessment were instantaneous readings, the NPAAQS is a 24-hour average.

TVOC Concentration

The TVOCs concentrations were 0 ppm inside the building. These concentrations were below the AIHA guideline for odor control of 1 ppm. The outdoor TVOC concentration was also 0 ppm.

OBSERVATIONS

During this assessment, ATC noted the following:

- The interior of the building appeared clean and free of dust and debris;
- The building was occupied at the time of the assessment;
- No smoke odor was detected in the building;


FINDINGS

Based on the real-time measurements, the following findings are presented:

1. Concentrations of CO₂, CO, and TVOCs were below applicable standards and guidelines.
2. Five (5) of the indoor measurements for temperature were below and One hundred and twenty three (123) of the measurements were within the range of 73 to 79 °F (at 50 percent relative humidity) recommended by ASHRAE Standard 55-1992 during the summer season.
3. All of the indoor measurements for relative humidity were within the ASHRAE-recommended range of 30 to 60 percent for occupant comfort.
4. None of the indoor measurements for PM_{2.5} were above the NPAAQS of 65 µg/m³ 24-hour average concentration of particulate matter 2.5 micrometers or less in aerodynamic diameter and above the USEPA recommended concentration of 40 µg/m³ for sensitive individuals such as asthmatic people and children.

It is our pleasure to provide these indoor air quality services to the New York City Board of Education. If you have any questions about this report, please call (212) 353-8280, ext # 290

Sincerely,
ATC ASSOCIATES INC.


Prasad Doddapaneni
Senior Project Manager

Attachment

Reviewed by:



James R. Cohn, CIH, CSP
Regional Manager
Industrial Hygiene Division