

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service

90 Trinity Place, New York, NY

Received: 5/11/02

4:30:00 PM

ATC Group #: 7716

Analysis Date: 5/11/02

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
04 7716 -1	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
05 7716 -2	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
06 7716 -3	1808.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
07 7716 -4	1816.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
08 7716 -5	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
09 7716 -6	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
10 7716 -7	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	

ROMAN PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Page 1 of 3

CITY_21MC100_003080204

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 5/11/02 4:30:00 PM
ATC Group #: 7716
Analysis Date: 5/11/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service
90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm ²)	(S/cc)	
11 7716 -8	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
12 7716 -9	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
13 7716 -10	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
14 7716 -11	1824.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
15 7716 -12	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
16 7716 -13	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
17 7716 -14	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
18 7716 -15	1832.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	
19 7716 -16	1840.00	0.0450	0	None Detected	0	0	0.0047	<22.24	<0.0047	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 5/11/02 4:30:00 PM
 ATC Group #: 7716
 Analysis Date: 5/11/02

Fax: (212) 475-4122 Phone: (212) 477-8941

Project: H.S. for Leadership & Public Service
 90 Trinity Place, New York, NY

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
20 7716 -17	1848.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	
21 7716 -18	1864.00	0.0450	0	None Detected	0	0	0.0046	<22.24	<0.0046	


ROMAN PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879