

ATC Associates

104 East 25 Street, New York, NY 10010

Phone: (212) 353-8280

Fax: (212) 353-8306



Attn: Mr. Bernard Orlan

N.Y.C. Board of Education

28-11 Queens Plaza North

Long Island City, NY 11101

Fax: (212) 475-4122

Phone: (212) 477-8941

Received: 5/12/02

6:00:00 PM

ATC Group #: 7722

Analysis Date: 5/12/02

Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5µ-5 µ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³)	(S/cc)	Notes
01 7722 -1	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
02 7722 -2	1928.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
03 7722 -3	1952.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
04 7722 -4	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
05 7722 -5	1936.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
06 7722 -6	1944.00	0.0450	0	None Detected	0	0	0.0044	<22.24	<0.0044
07 7722 -7	2057.00	0.0450	0	None Detected	0	0	0.0042	<22.24	<0.0042

MARK PEYSAKHOV

Analyzed by:

MICHAEL A. GORYCKI, Ph.D.

Approved by:

Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879

Attn: Mr. Bernard Orlan
N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101

Received: 5/12/02 6:00:00 PM
ATC Group #: 7722
Analysis Date: 5/12/02

Fax: (212) 475-4122 Phone: (212) 477-8941


Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures 0.5μ-5 μ	Analytical Sensitivity (S/cc)	Asbestos Concentration (S/mm ³) (S/cc)	Notes
08 7722 -8	1936.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
09 7722 -9	1936.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
10 7722 -10	1936.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
11 7722 -11	1936.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
12 7722 -12	1936.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	
13 7722 -13	1800.00	0.0450	0	None Detected	0	0	0.0048 <22.24 <0.0048	
14 7722 -14	1920.00	0.0450	0	None Detected	0	0	0.0045 <22.24 <0.0045	
15 7722 -15	2160.00	0.0450	0	None Detected	0	0	0.0040 <22.24 <0.0040	
16 7722 -16	1928.00	0.0450	0	None Detected	0	0	0.0044 <22.24 <0.0044	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm³. This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This report relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLMTEM #101187-0, NY State ELAP #10379

Attn: Mr. Bernard Orlan
 N.Y.C. Board of Education
 28-11 Queens Plaza North
 Long Island City, NY 11101

Received: 5/12/02 6:00:00 PM
ATC Group #: 7722
Analysis Date: 5/12/02

Fax: (212) 475-4122 **Phone:** (212) 477-8941

Project: H.S. for Leadership & Public Service

**Asbestos Fiber Analysis by Transmission Electron Microscopy (TEM) Performed
 by EPA 40 CFR Part 763 Final Rule (AHERA)**

Sample	Volume	Area Analyzed	Non Asb	Asbestos Type(s)	# Structures		Analytical Sensitivity (S/cc)	Asbestos Concentration		Notes
					0.5µ-5	5µ		(S/mm²)	(S/cc)	
17 7722 -17	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	
18 7722 -18	1920.00	0.0450	0	None Detected	0	0	0.0045	<22.24	<0.0045	


MARK PEYSAKHOV

Analyzed by:



MICHAEL A. GORYCKI, Ph.D.

Approved by:



Disclaimer: The laboratory is not responsible for data reported in structures/cc, which is dependent on volume collected by non-laboratory personnel. This lab is only responsible for data reported in structures/mm². This report may not be reproduced, except in full, without written approval by ATC Associates Inc. This report may not be used to claim product endorsement by NVLAP or any other agency of the U.S. Government. This reports relates only to the samples reported above. Quality control data (including 95% confidence limits and laboratory and analysis' accuracy and precision) is available upon request.

Accredited for NVLAP PLM/TEM #101187-0, NY State ELAP #10879