

New filter

Page 1 of 3

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME _____

LOCATION STUYVESANT HIGH SCHOOLDATE 11/13/01PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates(ug/m ³)	TVOCs (ppm)
10:40 739	34	75.9	27.8	1294	1	36	0.0
Air purifier 740	28	74.0	24.2	1065	1	31	0.0
738	16	75.9	24.2	1062	1	32	0.0
737	24	76.4	28.2	1470	1	33	0.0
736	32	75.9	25.1	1206	1	41	0.0
11:15 636	28	73.5	23.8	976	1	39	0.0
638 Air Purifier	30	78.3	23.5	930	1	34	0.0
639	32	76.7	25.3	1211	1	37	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

window open

window open

window open

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 11/13/01

New filter

Page 2 of 3

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 12:20LOCATION STUYVESANT HIGH SCHOOLDATE 11/13/01PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
429	16	74.9	24.2	1009	1	39	0.0
431	18	72.7	21.6	703	1	45	0.0
433	30	76.4	25.4	1070	1	37	0.0
435	3	75.5	23.8	605	1	36	0.0
436	4	73.5	21.6	644	1	39	0.0
437	26	74.3	24.8	1067	1	49	0.0
439	32	75.6	25.1	1060	1	40	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: _____

Date: 11/13/01

Ne filter

Page 3 of 3

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 12:55

LOCATION STUYVESANT HIGH SCHOOL

DATE 11/13/01

PROJECT NO. 19125-0246

3rd floor

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
339	28	74.4	23.2	829	1	38	0.0
337	36	74.1	27.2	1300	1	36	0.0
336	10	73.7	23.6	770	1	36	0.0
335	22	73.3	25.2	1095	1	44	0.0
<i>Air purifier</i> 333	32	74.5	29.9	1325	1	26	0.0
329	26	75.2	25.2	973	1	37	0.0
<i>Air purifier</i> 327	34	74.6	24.4	966	1	34	0.0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) ☐ Does ☐ Does not meet established indoor air quality guidelines.

Signature: *[Signature]*

Date: 11/13/01