

*new filter*Page 4 of 3

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME _____

LOCATION STUYVESANT HIGH SCHOOLDATE 11/26/01 PROJECT NO. 19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
<i>10:40 AM</i> 739	28	77.3	44.1	990	1	51	0.0
<i>Air Purifier</i> 740	—	73.3	46.9	665	1	44	0.0
738	26	76.3	47.5	1190	1	38	0.0
737	34	76.1	48.4	1560	1	43	0.0
736	18	75.8	45.1	1086	1	44	0.0
<i>11:10 AM</i> 636	36	77.3	44.6	1152	1	43	0.0
<i>Air Purifier</i> 638	30	79.3	44.4	1043	1	32	0.0 <i>(1 window open)</i>
639	28	79.1	41.3	860	1	37	0.0
640	32	78.7	39.7	1000	1	46	0.0
Guideline levels ASHRAE/AIHA		68 - 75°F/winter 73 - 79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 11/26/01

New filter

Page 4 of 3

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME _____

LOCATION STUYVESANT HIGH SCHOOLDATE 11/26/01 PROJECT NO. 19125-0246

12:15 PM

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
429	28	76.5	42.2	1055	1	48	0.0
431	28	75.1	41.2	945	1	43	0.0
433	34	75.0	41.9	1080	1	32	0.0
436	8	73.5	38.9	583	1	31	0.0
435	1	74.1	41.4	823	1	32	0.0
437	26	74.5	42.5	950	1	43	0.0
439	28	74.5	42.1	1015	1	34	0.0
Guideline levels ASHRAE/ATIA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments: _____

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature: _____

Date: 11/26/01

New filter

Page 3 of 3

ATC ASSOCIATES, INC.
INDOOR AIR QUALITY FIELD REPORT

TIME 12:50 PM

LOCATION

STUYVESANT HIGH SCHOOL

DATE

11/26/01

PROJECT NO.

19125-0246

Location	Occup.	Temperature (°F)	Relative Humidity (%)	Carbon Dioxide (ppm)	Carbon Monoxide (ppm)	Respirable Particulates (ug/m ³)	TVOCs (ppm)
337	32	74.4	42.9	1065	1	41	0.0
336	12	74.1	42.4	685	1	28	0.0
335	32	74.1	44.3	970	1	37	0.0
Air purifier 333	22	74.6	46.1	1046	1	21	0.0
329	4	74.3	43.6	715	1	27	0.0
327	34	74.4	44.9	1051	1	26	0.0
Guideline levels ASHRAE/AIHA		68 -75°F/winter 73 -79°F/summer	30-60%	Outdoor level + 700 ppm	9 ppm	65 ug/m ³ 24-hour average	1 ppm

Comments:

The assessed location(s) () Does () Does not meet established indoor air quality guidelines.

Signature:

Date:

11/26/01