

ATC ENVIRONMENTAL, INC.
104 East 25th Street
New York, NY 10010

APPROVED NY STATE DOH ELAP # 10879
ACCREDITED NVLAP Lab Code # 1187

Summary of TEM Results

N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Mr. Bernard Orlan

DATE: 10/20/01

Project/Site Identification: New Stuyvesant H.S., 345 Chambers St., NY, NY
Various Sites Inside and Outside the Building

CONCLUSION:

STATISTICAL SUMMARY

1) Inside Samples

TEM#	Project #	Volume (l)	Asbestos Concentration		
			S/mm ²	S/cc	ngm/m ³
5730- 61693	03	2016	0.0	0.0042 *	
5730- 61694	04	2008	0.0	0.0043 *	
5730- 61695	05	2000	0.0	0.0043 *	
5730- 61696	06	2000	0.0	0.0043 *	
5730- 61697	07	2024	0.0	0.0042 *	
5730- 61698	08	2024	0.0	0.0042 *	
5730- 61703	13	1936	0.0	0.0044 *	
5730- 61704	14	1936	0.0	0.0044 *	
5730- 61709	19	1944	0.0	0.0044 *	
5730- 61710	20	1960	0.0	0.0044 *	
5730- 61711	21	1968	0.0	0.0044 *	
5730- 61712	22	1960	0.0	0.0044 *	
5730- 61713	23	1976	0.0	0.0043 *	
Average=			0.0	0.0043	0

2) Outside Samples

TEM#	Project #	Volume (l)	Asbestos Concentration		
			S/mm ²	S/cc	ngm/m ³
5730- 61699	09	2032	0.0	0.0042 *	
5730- 61700	10	2024	0.0	0.0042 *	
5730- 61701	11	2016	0.0	0.0042 *	
5730- 61702	12	2016	0.0	0.0042 *	
5730- 61705	15	1928	0.0	0.0044 *	
5730- 61706	16	1928	0.0	0.0044 *	
5730- 61707	17	1928	0.0	0.0044 *	
5730- 61708	18	1944	0.0	0.0044 *	
Average=			0.0	0.0043	0

3) Blanks

TEM#	Project #	Asbestos Concentration		
		S/mm ²	S/cc	ngm/m ³
5730- 61691	01	- - - - -	Not Analyzed	- - - - -
5730- 61692	02	- - - - -	Not Analyzed	- - - - -
5730- 61714	24	- - - - -	Not Analyzed	- - - - -
Average=		N/A	N/A	N/A

4) Value of T - Statistic : N/A

* None detected; concentration equivalent to analytical sensitivity assigned.

This test report relates only to the specific items cited in the analysis.

The analysis was carried out according to the approved TEM method. The laboratory is in compliance with the quality specified for the method.

This report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government.

RP

Michael A. G. [Signature]

CITY_21MC100_003082355

Analyzed by:
Roman Peysakhov

Michael A. Gorycki, Ph.D.
Director of Electron Microscopy