NYC 9/11 Public Portal Document

ATC ENVIRONMENTAL, INC.
104 East 25th Street
New York, NY 10010

APPROVED NY STATE DOH ELAP # 10879
ACCREDITED NVLAP Lab Code # 1187

Summary of TEM Results

N.Y.C. Board of Education
28-11 Queens Plaza North
Long Island City, NY 11101
Mr. Bernard Orlan

DATE: 10/25/01

Project/Site Identification: New Stuyvesant H.S., 345 Chambers St., NY, NY
Exterior & Interior of Building & Roof

CONCLUSION:

STATISTICAL SUMMARY

1) Inside Samples

TEM#	Project #	Volume(l)	Asbestos Concentration S/mm^2	S/cc	ngm/m^3
5766- 62333	1	1928	0.0	0.0044 *	
5766- 62334	2	1928	0.0	0.0044 *	
5766- 62335	3	1920	0.0	0.0045 *	
5766- 62336	4	1928	0.0	0.0044 *	
5766- 62340	8	1936	0.0	0.0044 *	
5766- 62341	9	1928	0.0	0.0044 *	
5766- 62346	14	1936	0.0	0.0044 *	
5766- 62347	15	1928	0.0	0.0044 *	
5766- 62349	17	1920	0.0	0.0045 *	
5766- 62350	18	1928	0.0	0.0044 *	
5766- 62351	19	1928	0.0	0.0044 *	
5766- 62352	20	1928	0.0	0.0044 *	
5766- 62353	21	1936	0.0	0.0044 *	
		Average=	0.0	0.0044	0

2) Outside Samples

TEM#	Project #	Volume(l)	Asbestos Concentration S/mm^2	S/cc	ngm/m^3
5766- 62337	5	1936	0.0	0.0044 *	
5766- 62338	6	1928	0.0	0.0044 *	
5766- 62339	7	1936	0.0	0.0044 *	
5766- 62342	10	1944	0.0	0.0044 *	
5766- 62343	11	1928	0.0	0.0044 *	
5766- 62344	12	1944	0.0	0.0044 *	
5766- 62345	13	1936	0.0	0.0044 *	
5766- 62348	16	1928	0.0	0.0044 *	
		Average=	0.0	0.0044	0

3) Blanks

TEM#	Project #		Asbestos Concentration S/mm^2	S/cc	ngm/m^3
5766- 62354	22		- - - - - - - - -	Not Analyzed	- - - - - - - - -
5766- 62355	23		- - - - - - - - -	Not Analyzed	- - - - - - - - -
5766- 62356	24		- - - - - - - - -	Not Analyzed	- - - - - - - - -
		Average=	N/A	N/A	N/A

4) Value of T - Statistic : N/A

* None detected; concentration equivalent to analytical sensitivity assigned.

This test report relates only to the specific items cited in the analysis.
The analysis was carried out according to the approved TEM method. The laboratory is in compliance with the quality specified for the method.

This report must not be used by the client to claim product endorsement by NVLAP or any agency of the U.S. Government.

CITY_21MC100_003082643

NYC-WTC_000188701

NYC 9/11 Public Portal Document

Analyzed by:
Michael A. Gorycki, Ph.D.

Michael A. Gorycki, Ph.D.
Director of Electron Microscopy

NYC-WTC_000188702